

# Salem/Hope Creek Nuclear Generating Stations

## Exercise – March 21, 2006

Final Report - Radiological Emergency Preparedness Program

*June 20, 2006*



**Homeland  
Security**

*Philadelphia Field Office*



# Homeland Security

## **Final Exercise Report**

### **Salem/Hope Creek**

### **Nuclear Generating Stations**

Licensee: PSEG Nuclear, LLC

Exercise Date: March 21, 2006

Report Date: June 20, 2006

---

**U.S. DEPARTMENT OF HOMELAND SECURITY  
OFFICE OF INFRASTRUCTURE PROTECTION  
CHEMICAL & NUCLEAR PREPAREDNESS AND PROTECTION DIVISION  
RADIOLOGICAL EMERGENCY PREPAREDNESS**

**PHILADELPHIA FIELD OFFICE  
ONE INDEPENDENCE MALL, 6<sup>TH</sup> FLOOR  
615 CHESTNUT STREET  
PHILADELPHIA, PENNSYLVANIA 19106-4404**

---

# TABLE OF CONTENTS

I. Executive Summary.....	1
II. Introduction .....	3
III. Exercise Overview .....	5
A. Plume Emergency Planning Zone Description.....	5
B. Exercise Participants.....	6
C. Exercise Timeline .....	8
IV. Evaluation and Results .....	10
A. Summary Results of Exercise Evaluation .....	10
B. Status of Jurisdictions Evaluated.....	12
1.0 STATE OF DELAWARE.....	14
1.1 State Emergency Operations Center .....	14
1.2 Technical Assessment Center (TAC-EOC) .....	17
1.3 Emergency Operations Facility (EOF) .....	18
1.4 Emergency News Center (Woodstown, NJ) .....	18
1.5 State Field Monitoring Team 1 .....	18
1.6 State Field Monitoring Team 2 .....	19
1.7 State Traffic and Access Control (Odessa Troop 9) .....	19
1.8 Emergency Worker Decontamination Center (DNG Middletown Readiness Center) .....	19
1.9 Reception Center (DNG Stern Readiness Center/Marshallton).....	20
1.10 Congregate Care Facility (Brandywine High School).....	20
2.0 RISK JURISDICTIONS .....	20
2.1 Kent County Emergency Operations Center.....	20
2.2 New Castle County Emergency Operations Center.....	21
2.3 Route Alerting (Port Penn Fire Company, New Castle County).....	21
3.0 SCHOOLS .....	22
3.1 State Department of Education .....	22
3.2 Appoquinimink School District (New Castle County) Meredith Everett Middle School.....	22

3.3 Colonial School District (New Castle County) Gunning Bedford Middle School ..... 22

**APPENDICES**

APPENDIX 1 - Acronyms and Abbreviations.....23  
 APPENDIX 2 - Exercise Evaluators and Team Leaders .....25  
 APPENDIX 3 - Exercise Evaluation Area Criteria and Extent of Play Agreement .....27  
 APPENDIX 4 - Exercise Scenario .....84  
 APPENDIX 5 - Planning Issues.....85

**LIST OF TABLES**

Table 1 – Exercise Timeline.....9  
 Table 2 – Summary Results of Exercise Evaluation .....11

# I. Executive Summary

On March 21, 2006, a full-scale plume exercise was conducted in the 10-mile plume exposure pathway, emergency planning zone (EPZ) around the Salem/Hope Creek Nuclear Generating Stations (S/HCNGS), formerly known as the Artificial Island Nuclear Generating Stations, by the Department of Homeland Security/Office of Infrastructure Protection/Chemical & Nuclear Preparedness and Protection Division/Radiological Emergency Preparedness (DHS/IP/CNPPD/REP) Philadelphia Field Office. Out-of-sequence demonstrations were conducted on March 8 and 9, 2006. The purpose of the exercise and the out-of-sequence demonstrations was to assess the level of State and local preparedness in responding to a radiological emergency. The exercise and out-of-sequence demonstrations were held in accordance with DHS/IP/CNPPD/REP policies and guidance concerning the exercise of State and local radiological emergency response plans (RERP) and procedures.

The most recent prior full-scale exercise at this site was conducted on March 16, 2004. The qualifying emergency preparedness exercise was conducted in 1986.

DHS/IP/CNPPD/REP wishes to acknowledge the efforts of the many individuals in the State of Delaware and the risk jurisdictions of Kent and New Castle Counties who were evaluated at this exercise. DHS/IP/CNPPD/REP also wishes to acknowledge the efforts of the many individuals that participated in the March 8 and 9, 2006 out-of-sequence demonstration of activities at the State Emergency Operations Center and New Castle County school districts.

Protecting the public health and safety is the full-time job of some of the exercise participants and an additional assigned responsibility for others. Still others have willingly sought this responsibility by volunteering to provide vital emergency services to their communities. Cooperation and teamwork of all the participants were evident during this exercise.

This report contains the final evaluation of the biennial exercise and the evaluation of the following out-of-sequence activities:

- *Emergency Worker Decontamination:* Conducted on March 8, 2006 at the DNG Middletown Readiness Center.
- *Reception Center:* Conducted on March 9, 2006 at the DNG Stern Readiness Center/Marshalltown.
- *Schools:* Conducted on March 8, 2006 at the State EOC and in New Castle County.

The State and local organizations, except where noted in this report, demonstrated knowledge of their emergency response plans and procedures and adequately implemented them. There were no Deficiencies, four Areas Requiring Corrective Action (ARCA), and one planning issue identified as a result of this exercise. One planning issue from a previous exercise was successfully demonstrated (see Appendix 5 for resolution). On June 7, 2006, a quarterly full-scale radiological drill was conducted by PSEG and the Delaware Emergency Management

Agency (DEMA), during which the four ARCAs were re-demonstrated. The results of the re-demonstration were successful, and the four ARCAs were corrected and closed.

## II. Introduction

On December 7, 1979, the President directed the Federal Emergency Management Agency (FEMA) to assume the lead responsibility for all off-site nuclear planning and response. FEMA's activities were conducted pursuant to 44 Code of Federal Regulations (CFR) Parts 350, 351 and 352. These regulations are a key element in the Radiological Emergency Preparedness (REP) Program that was established following the Three Mile Island Nuclear Station accident in March 1979. In October 2005, the REP Program was moved to DHS/IP/CNPPD/REP. Modification of the 44 CFR series is underway to reflect the new organizational structure of the REP Program.

44 CFR 350 establishes the policies and procedures for FEMA's (now DHS/IP/CNPPD/REP's) initial and continued approval of Tribal, State, and local governments' radiological emergency planning and preparedness for commercial nuclear power plants. This approval is contingent, in part, on State and local government participation in joint exercises with licensees.

DHS/IP/CNPPD/REP's responsibilities in radiological emergency planning for fixed nuclear facilities include the following:

- Taking the lead in offsite emergency planning and in the review and evaluation of Radiological Emergency Response Plans (RERPs) and procedures developed by State and local governments;
- Determining whether such plans and procedures can be implemented on the basis of observation and evaluation of exercises of the plans and procedures conducted by State and local governments;
- Responding to requests by the U.S. Nuclear Regulatory Commission (NRC) pursuant to the Memorandum of Understanding between the NRC and FEMA dated June 17, 1993 (Federal Register, Vol. 58, No. 176, September 14, 1993; now under revision to reflect DHS responsibilities); and
- Coordinating the activities of the following Federal agencies with responsibilities in the radiological emergency planning process:
  - U.S. Department of Commerce,
  - U.S. Nuclear Regulatory Commission,
  - U.S. Environmental Protection Agency,
  - U.S. Department of Energy,
  - U.S. Department of Health and Human Services,
  - U.S. Department of Transportation,
  - U.S. Department of Agriculture,
  - U.S. Department of the Interior, and
  - U.S. Food and Drug Administration.

Representatives of these agencies serve on the Radiological Preparedness Coordination Committee (RPCC), which is chaired by DHS/IP/CNPPD/REP Field Office Leads.

A REP exercise was conducted on March 21, 2006, to assess the capabilities of State and local emergency preparedness organizations in implementing their RERPs and procedures to protect the public health and safety during a radiological emergency involving the S/HCNGS. The purpose of this exercise report is to present the exercise results and findings on the performance of the off-site response organizations (ORO) during a simulated radiological emergency.

The findings presented in this report are based on the evaluations of the Federal evaluator team, with final determinations made by the RPCC Chairperson from the Philadelphia Field Office, and approved by DHS/IP/CNPPD Headquarters.

The criteria utilized in the DHS/IP/CNPPD/REP evaluation process are contained in the following:

- NUREG-0654/FEMA-REP-1, Rev. 1, "Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants," November 1980;
- FEMA Guidance Memoranda MS-1, "Medical Services," November 1986;
- FEMA-REP-14, "Radiological Emergency Preparedness Exercise Manual," September 1991;
- 66 FR 47546, "FEMA Radiological Emergency Preparedness: Alert and Notification," September 12, 2001; and
- 67 FR 20580, "FEMA Radiological Emergency Preparedness: Exercise Evaluation Methodology," April 25, 2002.

Section III of this report, entitled "Exercise Overview," presents basic information and data relevant to the exercise. This section of the report contains a description of the plume pathway emergency planning zone (EPZ), a listing of all participating jurisdictions and functional entities that were evaluated, and a tabular presentation of the time of actual occurrence of key exercise events and activities.

Section IV of this report, entitled "Exercise Evaluation and Results," presents detailed information on the demonstration of applicable exercise evaluation areas at each jurisdiction or functional entity evaluated in a jurisdiction-based, issues-only format. This section also contains: (1) descriptions of all Deficiencies and ARCAs assessed during this exercise, recommended corrective actions, and the Tribal, State, and local governments' schedule of corrective actions for each identified exercise issue and (2) descriptions of unresolved ARCAs assessed during previous exercises and the status of the OROs' efforts to resolve them.

### III. Exercise Overview

This section of the exercise report contains data and basic information relevant to the March 21, 2006 exercise to test the off-site emergency response capabilities in the area surrounding the Salem/Hope Creek Nuclear Generating Stations (S/HCNGS). It also includes a description of the plume pathway EPZ, a listing of all participating jurisdictions and functional entities that were evaluated, and a tabular presentation of the time of actual occurrence of key exercise events and activities.

#### A. Plume Emergency Planning Zone Description

The S/HCNGS site is located on the east bank of the Delaware River in Lower Alloways Creek Township, Salem County, New Jersey, about 18 miles south of Wilmington, Delaware. The 700-acre site is on the southern end of Artificial Island, a 3-mile-long, 1-mile-wide, man-made peninsula. The peninsula is connected to the mainland by a strip of tideland formed by hydraulic fill from dredging operations on the Delaware River. The tideland was constructed by the U.S. Army Corps of Engineers. The coordinates of the site are latitude 39°27'46" north and longitude 75°32'08" west. Two pressurized water reactors (Salem) and one boiling water reactor (Hope Creek) are located on the island. Each Salem unit generates a maximum output of 1,106 megawatts (MW); Unit 1 commenced commercial operations in June 1977 and Unit 2 in October 1981. The Hope Creek Unit, which generates a maximum output of 1,031 MW, became operational in December 1986.

The site lies on the low coastal plain of New Jersey, surrounded by extensive marshlands and meadowlands. The land within the two Delaware counties (New Castle and Kent) near the site is either undeveloped (48 percent) or used for agricultural purposes (42 percent). Major farm products within a 25-mile radius of the site include vegetables, poultry, dairy products, and indigenous field crops.

The nearest major population center (more than 25,000 people) is Wilmington, Delaware, which has a population of 71,529 and lies 20 miles north of the S/HCNGS. The maximum population distribution in Delaware, including residents and transients, is 0 within the 2-mile EPZ, 850 within the 5-mile EPZ, and 24,976 within the 10-mile EPZ. There are 37 early warning sirens in the Delaware portion of the EPZ.

The Ingestion Planning Zone (IPZ) is approximately 7,850 square miles in area, which is equivalent to a 50-mile radius around the plant site. The States of Delaware, Maryland, and New Jersey, and the Commonwealth of Pennsylvania have jurisdictions within the IPZ. The largest city within the IPZ is Philadelphia, Pennsylvania, with a population of 1,587,855, about 46 miles from the plant site.

## **B. Exercise Participants**

The following agencies, organizations, and units of government participated in the S/HCNGS out-of-sequence activities on March 8 and 9, 2006, or the exercise on March 21, 2006.

### **STATE OF DELAWARE**

Delaware Alcohol and Tobacco Enforcement  
Delaware Army National Guard  
Delaware Army National Guard Headquarters  
Delaware Cooperative Extension  
Delaware Department of Agriculture  
Delaware Department of Education  
Delaware Department of Health and Social Services — Division of Administrative Services  
Delaware Department of Health and Social Services — Division of Public Health  
Delaware Department of Natural Resources and Environmental Control — Division of Fish & Wildlife  
Delaware Department of Natural Resources and Environmental Control — Division of Water Resources  
Delaware Department of Public Safety and Homeland Security  
Delaware Department of Transportation — Delaware Transit Corporation  
Delaware Department of Transportation  
Delaware Emergency Management Agency  
Delaware National Guard  
Delaware Office of Emergency Medical Services  
Delaware State Fire School  
Delaware State Police  
Kent County Liaison  
New Castle County Liaison  
New Jersey Bureau of Nuclear Engineering  
New Jersey Office of Emergency Management (NJOEM) Liaison  
U.S. Army Corps of Engineers  
U.S. Coast Guard  
Wilmington Office of Emergency Management

### **KENT COUNTY**

Delaware Department of Transportation  
Delaware Emergency Management Agency (Controller)  
Delaware State Police – Troop 3  
Kent County Department of Public Safety  
Kent County Emergency Management  
Kent County Emergency Medical Services  
Kent County Levy Court

## **NEW CASTLE COUNTY**

New Castle County Community Services  
New Castle County Department of Public Safety  
New Castle County Emergency Communications (911)  
New Castle County Emergency Medical Services (EMS)  
New Castle County Government Executive Office  
New Castle County Office of Emergency Management (OEM)  
New Castle County Police  
New Castle County Special Services (Public Works)

## **SCHOOLS (NEW CASTLE COUNTY)**

Appoquinimink School District  
Colonial School District  
Delaware Department of Education  
Delaware Emergency Management Agency Liaison  
Gunning Bedford Middle School  
Meredith Everett Middle School

## **PRIVATE/VOLUNTEER ORGANIZATIONS**

The following private and volunteer organizations participated in the S/HCNGS exercise activities at many different locations throughout the area. We thank them and all those who volunteer their services to State, county, and municipal governments during emergencies.

American Red Cross  
American Red Cross of the Delmarva Peninsula  
Civil Air Patrol  
Kent County Amateur Radio Club  
Military Amateur Radio Stations (MARS)  
Port Penn Fire Company (Station 29)  
PSEG Nuclear  
Radio Amateur Civil Emergency Services (RACES)  
Salvation Army  
Stapleford Bus Company  
Stapleford Chevrolet (contract bus driver)  
Verizon Communications

### **C. Exercise Timeline**

Table 1, on the following page, presents the time at which key events and activities occurred during the S/HCNGS exercise on March 21, 2006. Also included are times notifications were made to the participating jurisdictions/functional entities.

**TABLE 1. EXERCISE TIMELINE**

DATE AND SITE: *March 21, 2006 Salem/Hope Creek Nuclear Generating Stations*

Emergency Classification Level or Event	Time Utility Declared	Time Notification Was Received or Action Was Taken					
		Delaware State EOC	EOF	State TAC	Emergency News Center	Kent County EOC	New Castle County EOC
Unusual Event	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Alert	1537	1548	N/A	1548	N/A	1624	1628
Site Area Emergency	1741	1745	1747	1745	1756	1754	1755
General Emergency	1835	1841	1836	1845	1845	1840	1845
Simulated Radiation Release Started	1823	1835	1832	1835	1845	1840	1845
Simulated Radiation Release Terminated		N/A	2211	N/A	N/A	N/A	N/A
Facility Declared Operational		1600	1657	1600	1647	1615	1640
Declaration of State of Emergency		1914	1920	1914	1930	1921	1921
Exercise Terminated		2220	2219	2220	2220	2040	2115
<b>Early Precautionary Actions:</b>							
Coast Guard restricted Delaware River based traffic		1756	1913	1756	1812	1756	1756
Animals on stored feed and water		1835	1914	1835	1914	1840	1845
1st A&N Decision (State [made]; local [received]) Evacuate Special Populations in Area A & Shelter in Place Area "A"		1835	1913	1835	1848	1840	1845
1st Siren Activation		1845					
1st EAS or EBS Message		1855					
2nd A&N Decision (State [made]; local [received]) Evacuate ERPA-A Administer KI to Emergency Workers in all areas, and General Public in Area A.		1936	1944	1836	1941	1936	1943
2nd Siren Activation		1940					
2nd EAS or EBS Message		1950					
<b>Precautionary Actions:</b>							
<b>KI Administration Decision:</b> Emergency workers advised <u>not</u> to take		N/A		N/A		N/A	

Legend: N/A – Not Applicable    D – Decision-Making Jurisdiction    A – Activating Jurisdiction

## IV. Evaluation and Results

Contained in this section are the results and findings of the evaluation of all jurisdictions and locations that participated in the March 21, 2006, biennial REP exercise. The exercise was held to test the offsite emergency response capabilities of local governments in the 10-mile EPZ surrounding the S/HCNGS.

Each jurisdiction and functional entity was evaluated on the basis of its demonstration of the exercise evaluation area criteria contained in the REP Exercise Evaluation Methodology. Detailed information on the exercise evaluation area criteria and the extent-of-play agreement used in this exercise are found in Appendix 3 of this report.

### A. Summary Results of Exercise Evaluation

The matrix presented in Table 2, on the following pages, presents the status of the exercise evaluation area criteria from the REP Exercise Evaluation Methodology that were scheduled for demonstration during this exercise by all participating jurisdictions and functional entities. Exercise evaluation area criteria are listed by number and the demonstration status of the criteria is indicated by the use of the following letters:

- M Met (No Deficiency or ARCAs assessed and no unresolved ARCAs from prior exercises)
- A<sup>1</sup> ARCA(s) assessed, but successfully re-demonstrated

## TABLE 2. SUMMARY RESULTS OF EXERCISE EVALUATION

DATE AND SITE: *March 21, 2006 Salem/Hope Creek Nuclear Generation Stations*

JURISDICTION/LOCATION	1. a. 1	1. b. 1	1. c. 1	1. d. 1	1. e. 1	2. a. 1	2. b. 1	2. b. 2	2. c. 1	2. d. 1	2. e. 1	3. a. 1	3. b. 1	3. c. 1	3. c. 2	3. d. 1	3. d. 2	3. e. 1	3. e. 2	3. f. 1	4. a. 1	4. a. 2	4. a. 3	4. b. 1	4. c. 1	5. a. 1	5. a. 2	5. a. 3	5. b. 1	6. a. 1	6. b. 1	6. c. 1	6. d. 1			
<b>STATE OF DELAWARE</b>																																				
State Emergency Operations Center (SEOC)	M	M	A <sup>1</sup>	M	M		M	M	M						M	M	M	M										A <sup>1</sup>			2 A <sup>1</sup>					
Technical Assessment Center (TAC-EOC)	M			M			M	M																												
Emergency Operations Facility (EOF)	M																																			
Emergency News Center (Woodstown, NJ)	M																															M				
State Field Monitoring Team 1	M			M	M	M						M	M																							
State Field Monitoring Team 2	M			M	M	M						M	M																							
State Traffic and Access Control (Odessa Troop 9)				M	M	M						M	M			M	M																			
Emergency Worker Decontamination Center (DNG Middletown Readiness Center)		M		M	M	M						M	M																				M	M		
Reception Center (DNG Stern Readiness Center/Marshallton)		M		M	M	M						M	M																				M			
Congregate Care Facility (Brandywine High School)		M																															M			
<b>RISK JURISDICTIONS</b>																																				
Kent County Emergency Operations Center	M	M	M	M										M	M																					
New Castle County Emergency Operations Center	M	M	M	M										M	M												M									
Route Alerting (Port Penn Fire Company, New Castle County)				M	M	M						M	M																			M				
<b>SCHOOLS</b>																																				
State Dept. of Education (State EOC)																																				
Appoquinimink School District (New Castle County) Meredith Everett Middle School																																				
Colonial School District (New Castle County) Gunning Bedford Middle School																																				

LEGEND: M = Met (no Deficiency or ARCA(s) assessed)  
R = Resolved ARCA(s) from prior exercises

A<sup>1</sup> = ARCA(s) assessed, but successfully re-demonstrated  
Blank = Not scheduled for demonstration

## B. Status of Jurisdictions Evaluated

This subsection provides information on the evaluation of each participating and functional entity in a jurisdiction-based, issues-only format. Presented below are definitions of the terms used in this subsection relative to criteria demonstration status.

- **Met** – Listing of the demonstrated exercise evaluation area criteria under which no Deficiencies or ARCAs were assessed during this exercise and under which no ARCAs assessed during prior exercises remain unresolved.
- **Deficiency** – Listing of the demonstrated exercise evaluation area criteria under which one or more Deficiencies were assessed during this exercise. Included is a description of each Deficiency and recommended corrective actions.
- **Area Requiring Corrective Action** – Listing of the demonstrated exercise evaluation area criteria under which one or more ARCAs were assessed during the current exercise. Included is a description of the ARCAs assessed during this exercise and the recommended corrective actions to be demonstrated before or during the next biennial exercise.
- **Not Demonstrated** – Listing of the exercise evaluation area criteria that were scheduled to be demonstrated during this exercise, but were not demonstrated and the reason they were not demonstrated.
- **Prior ARCAs – Resolved** – Descriptions of ARCAs assessed during previous exercises that were resolved in this exercise and the corrective actions demonstrated.
- **Prior ARCAs – Unresolved** – Descriptions of ARCAs assessed during prior exercises that were not resolved in this exercise. Included are the reasons the ARCAs remain unresolved and recommended corrective actions to be demonstrated before or during the next biennial exercise.

The following are definitions of the two types of exercise issues that are discussed in this report.

- A **Deficiency** is defined in FEMA-REP-14 as “...an observed or identified inadequacy of organizational performance in an exercise that could cause a finding that offsite emergency preparedness is not adequate to provide reasonable assurance that appropriate protective measures can be taken in the event of a radiological emergency to protect the health and safety of the public living in the vicinity of a nuclear power plant.”

- An **ARCA** is defined in FEMA-REP-14 as “...an observed or identified inadequacy of organizational performance in an exercise that is not considered, by itself, to adversely impact public health and safety.”

FEMA has developed a standardized system for numbering exercise issues (Deficiencies and ARCAs). This system is used to achieve consistency in numbering exercise issues among FEMA Regions and site-specific exercise reports within each Region. It is also used to expedite tracking of exercise issues on a nationwide basis.

The identifying number for Deficiencies and ARCAs includes the following elements, with each element separated by a hyphen (-).

- **Plant Site Identifier** – A two-digit number corresponding to the Utility Billable Plant Site Codes.
- **Exercise Year** – The last two digits of the year the exercise was conducted.
- **Evaluation Area Criterion** – A letter and number corresponding to the criteria in the FEMA REP Exercise Evaluation Methodology.
- **Issue Classification Identifier** – (D = Deficiency, A = ARCA). Only Deficiencies and ARCAs are included in exercise reports.
- **Exercise Issue Identification Number** – A separate two digit indexing number assigned to each issue identified in the exercise.

## 1.0 STATE OF DELAWARE

### 1.1 State Emergency Operations Center

- a. **MET:** 1.a.1 2.b.1 3.c.1  
1.b.1 2.b.2 3.c.2  
1.d.1 2.c.1 3.d.1  
1.e.1 3.d.2
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** 4 (1.c.1, 5.a.1, 5.b.1 [2])

#### Issue No.: 02-06-1.c.1-A-01

**Condition:** The State of Delaware Emergency Operations Center (SEOC) did not notify the risk counties in a timely manner of the ALERT Emergency Classification Level (ECL). The SEOC received this notification at 1548. Kent County was notified at 1624 and New Castle County was notified at 1628.

**Possible Cause:** An all-hands briefing at the SEOC of all emergency workers may have delayed notification.

**Reference:** NUREG-0654, A.1.d and A.2.a, b

**Effect:** This could have delayed the activation of the risk counties.

**Recommendation:** Ensure that the risk counties are notified in a timely manner of all ECLs.

**State Response:** Delaware Emergency Management Agency (DEMA) will provide training regarding prompt alert and notification to the public.

**Corrective Action Demonstrated:** This ARCA was re-demonstrated during a quarterly full-scale radiological drill on June 7, 2006, based on a scenario developed by PSEG and approved by DHS and an Extent of Play agreement developed by DEMA and approved by DHS. The risk counties of New Castle and Kent were notified in a timely manner of each announced ECL. The Alert ECL, received at the State EOC at 0926, was telephoned to New Castle County at 0945 and to Kent County at 0946. The Site Area Emergency ECL was received by the State EOC at 1115 and telephoned to New Castle and Kent Counties at

1122 and 1125 respectively. The General Emergency ECL was received by the State EOC at 1227 and telephoned to New Castle and Kent Counties at 1243 and 1245 respectively. This ARCA was correctly demonstrated and is closed.

**Issue No.: 02-06-5.a.1-A-02**

**Condition:** The Alert and Notification System (ANS) was not activated to inform the public of the Protective Action Decision (PAD) made at 2005 to shelter the population in Emergency Response Planning Area (ERPA) C.

**Possible Cause:** The Incident Command considered the decision to shelter ERPA C as an amendment to the PAD made earlier at 1936 and hence decided to only issue a press release #9. The earlier PAD made at 1936 was followed by siren sounding at 1940 and EAS message issued at 1950. The supplemental press release #7 was issued at 1942 and press release #8 was issued at 2000. The decision to shelter ERPA C was delayed by 29 minutes and made at 2005. Press release #9 providing more details was issued at 2029.

**References:**

- 10CFR50 Appendix E
- NUREG-0654, E.1, 5, 6, and 7

**Effect:** The general public would not have been alerted to the protective action to Shelter ERPA C without the sounding of the sirens and the issuance of an EAS message. The delay of about 29 minutes between this decision and the Alert and Notification (A&N) sequence was too long to consider them as the same protective action.

**Recommendation:** Ensure that all protective action decisions are followed by an A&N sequence and a press release.

**State Response:** DEMA will provide training regarding the decision-making process and the prompt alert and notification to the public.

**Corrective Action Demonstrated:** This ARCA was re-demonstrated during a quarterly full-scale radiological drill on June 7, 2006, based on a scenario developed by PSEG and approved by DHS and an Extent of Play agreement developed by DEMA and approved by DHS. The ANS was activated promptly after each of the two PADs was made. At 1145, a PAD was made

to (1) shelter persons in ERPA A, 0-5 miles, (2) evacuate all schools, day cares, and special populations in all ERPAs, (3) place animals on stored feed and water in all ERPAs, and (4) impose a water restriction on all boating on the Delaware River. At 1150, the ANS was initiated with the sirens sounding, followed by the EAS message at 1155. At 1259, a second PAD was made to (1) evacuate persons in ERPAs A and C and (2) take KI for all emergency workers and the general population in ERPA A. At 1305, the second ANS was initiated with the sirens sounding, followed by the EAS message at 1310. This ARCA was correctly demonstrated and is closed.

**Issue No.: 02-06-5.b.1-A-03**

**Condition:** A decision was made at the SEOC to issue press release #4, referencing the Site Area Emergency (SAE) at 1854, 13 minutes after the General Emergency (GE) declaration was received at the SEOC.

**Possible Cause:** The state decided to issue the press release knowing that the classification level had elevated to GE.

**References:** NUREG-0654, E.5 and 7

**Effect:** Inaccurate information was issued possibly causing confusion among the public.

**Recommendation:** The SEOC should only issue press releases that contain information about the current ECL.

**State Response:** DEMA will provide training on the accuracy of issued press releases.

**Corrective Action Demonstrated:** This ARCA was re-demonstrated during a quarterly full-scale radiological drill on June 7, 2006, based on a scenario developed by PSEG and approved by DHS and an Extent of Play agreement developed by DEMA and approved by DHS. Seven Press releases were issued. All contained the correct ECL information. Press Release Numbers 2- 5 contained current and correct information regarding the Site Area Emergency ECL and at 1314, Press Release Number 6 was issued containing the current and correct ECL information regarding the upgrade to General Emergency. This ARCA was correctly demonstrated and is closed.

**Issue No.: 02-06-5.b.1-A-04**

**Condition:** The first press release contained an inaccurate time of the Alert declaration. The release stated 1557, instead of the correct time of 1537.

**Possible Cause:** The press release was not proof read for accuracy.

**Reference:** NUREG-0654, E.5 and 7

**Effect:** The inaccurate time on the press release may cause confusion.

**Recommendation:** All press releases should be checked for accuracy prior to being released.

**State Response:** DEMA will provide training and encourage proofing of press releases for accuracy.

**Corrective Action Demonstrated:** This ARCA was re-demonstrated during a quarterly full-scale radiological drill on June 7, 2006, based on a scenario developed by PSEG and approved by DHS and an Extent of Play agreement developed by DEMA and approved by DHS. All Press Releases were checked for accuracy, and reviewed and initialed by the Incident Commander prior to release. All seven contained accurate information. This ARCA was correctly demonstrated and is closed.

- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**1.2 Technical Assessment Center (TAC-EOC)**

- a. **MET:** 1.a.1 2.b.1  
1.d.1 2.b.2
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None

- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**1.3 Emergency Operations Facility (EOF)**

- a. **MET:** 1.a.1
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**1.4 Emergency News Center (Woodstown, NJ)**

- a. **MET:** 1.a.1 5.b.1
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**1.5 State Field Monitoring Team 1**

- a. **MET:** 1.a.1 2.a.1 3.a.1 4.a.1  
           1.d.1           3.b.1 4.a.2  
           1.e.1                   4.a.3
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None

f. **PRIOR ARCAs - UNRESOLVED:** None

**1.6 State Field Monitoring Team 2**

a. **MET:** 1.a.1 2.a.1 3.a.1 4.a.1  
1.d.1 3.b.1 4.a.2  
1.e.1 4.a.3

b. **DEFICIENCY:** None

c. **AREAS REQUIRING CORRECTIVE ACTION:** None

d. **NOT DEMONSTRATED:** None

e. **PRIOR ARCAs - RESOLVED:** None

f. **PRIOR ARCAs - UNRESOLVED:** None

**1.7 State Traffic and Access Control (Odessa Troop 9)**

a. **MET:** 1.d.1 2.a.1 3.a.1  
1.e.1 3.b.1  
3.d.1  
3.d.2

b. **DEFICIENCY:** None

c. **AREAS REQUIRING CORRECTIVE ACTION:** None

d. **NOT DEMONSTRATED:** None

e. **PRIOR ARCAs - RESOLVED:** None

f. **PRIOR ARCAs - UNRESOLVED:** None

**1.8 Emergency Worker Decontamination Center (Delaware National Guard (DNG) Middletown Readiness Center)**

a. **MET:** 1.b.1 2.a.1 3.a.1 6.a.1  
1.d.1 3.b.1 6.b.1  
1.e.1

b. **DEFICIENCY:** None

c. **AREAS REQUIRING CORRECTIVE ACTION:** None

- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**1.9 Reception Center (DNG Stern Readiness Center/Marshallton)**

- a. **MET:** 1.b.1 2.a.1 3.a.1 6.a.1  
1.d.1 3.b.1  
1.e.1
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**1.10 Congregate Care Facility (Brandywine High School)**

- a. **MET:** 1.b.1 6.c.1
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**2.0 RISK JURISDICTIONS**

**2.1 Kent County Emergency Operations Center**

- a. **MET:** 1.a.1 3.c.1  
1.b.1 3.c.2  
1.c.1  
1.d.1

- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**2.2 New Castle County Emergency Operations Center**

- a. **MET:** 1.a.1 3.c.1 5.a.1  
           1.b.1 3.c.2  
           1.c.1  
           1.d.1
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

**2.3 Route Alerting (Port Penn Fire Company, New Castle County)**

- a. **MET:** 1.d.1 2.a.1 3.a.1 5.a.3  
           1.e.1 3.b.1
- b. **DEFICIENCY:** None
- c. **AREAS REQUIRING CORRECTIVE ACTION:** None
- d. **NOT DEMONSTRATED:** None
- e. **PRIOR ARCAs - RESOLVED:** None
- f. **PRIOR ARCAs - UNRESOLVED:** None

### **3.0 SCHOOLS**

#### **3.1 State Department of Education**

- a. MET: 3.c.2**
- b. DEFICIENCY: None**
- c. AREAS REQUIRING CORRECTIVE ACTION: None**
- d. NOT DEMONSTRATED: None**
- e. PRIOR ARCAs - RESOLVED: None**
- f. PRIOR ARCAs - UNRESOLVED: None**

#### **3.2 Appoquinimink School District (New Castle County) Meredith Everett Middle School**

- a. MET: 3.c.2**
- b. DEFICIENCY: None**
- c. AREAS REQUIRING CORRECTIVE ACTION: None**
- d. NOT DEMONSTRATED: None**
- e. PRIOR ARCAs - RESOLVED: None**
- f. PRIOR ARCAs - UNRESOLVED: None**

#### **3.3 Colonial School District (New Castle County) Gunning Bedford Middle School**

- a. MET: 3.c.2**
- b. DEFICIENCY: None**
- c. AREAS REQUIRING CORRECTIVE ACTION: None**
- d. NOT DEMONSTRATED: None**
- e. PRIOR ARCAs - RESOLVED: None**
- f. PRIOR ARCAs - UNRESOLVED: None**

# APPENDIX 1

## Acronyms and Abbreviations

A&N	Alert and Notification
ALARA	As Low As Reasonably Achievable
ALC	Annual Letter of Certification
ANS	Alert and Notification System
ARC	American Red Cross
ARCA	Area Requiring Corrective Action
ATL	Assistant Team Leader
CFR	Code of Federal Regulations
DelDOT	Delaware Department of Transportation
DHS	Department of Homeland Security
DHS/IP/CNPPD/ REP	Department of Homeland Security/Office of Infrastructure Protection/Chemical & Nuclear Preparedness and Protection Division/Radiological Emergency Preparedness
DNG	Delaware National Guard
DOE	Department of Education
DSP	Delaware State Police
E	East
EAS	Emergency Alerting System
EBS	Emergency Broadcast System
ECL	Emergency Classification Level
ENC/JIC	Emergency News Center/Joint Information Center
ENE	East Northeast
EOC	Emergency Operations Center
EOF	Emergency Operations Facility
EPA	Environmental Protection Agency
EPZ	Emergency Planning Zone
ERPA	Emergency Response Planning Area
FAA	Federal Aviation Administration
FDA	Food and Drug Administration
FEMA	Federal Emergency Management Agency
FMT	Field Monitoring Team
FRERP	Federal Radiological Emergency Response Plan – NRP National Response Plan
GE	General Emergency
ICF	ICF Consulting
IPZ	Ingestion Pathway Emergency Planning Zone

KI	Potassium Iodide
LOCA	Loss of Coolant Accident
MW	Megawatts
NE	Northeast
NJ	New Jersey
NJOEM	New Jersey Office of Environmental Management
NNW	North Northwest
NRC	U.S. Nuclear Regulatory Commission
NUREG-0654	NUREG-0654/FEMA-REP-1, Rev. 1 (Criteria for Preparation and Evaluation of Radiological Emergency Response Plans and Preparedness in Support of Nuclear Power Plants), November 1980
NW	Northwest
OEM	Office of Emergency Management
ORO	Offsite Response Organization
OSC	Operational Support Center
PAD	Protective Action Decision
PAG	Protective Action Guidance
PAR	Protective Action Recommendation
PSEG	Public Service Electric and Gas - PSEG Nuclear
R	Roentgen(s)
RACES	Radio Amateur Civil Emergency Services
Rem	Roentgen Equivalent Man
REP	Radiological Emergency Preparedness
RERP	Radiological Emergency Response Plan
RPCC	Radiological Preparedness Coordination Committee
R/hr	Roentgens per hour
S/HCNGS	Salem/Hope Creek Nuclear Generating Stations (formerly Artificial Island)
SAE	Site Area Emergency
SEOC	State Emergency Operations Center
SOP	Standard Operating Procedure
SRD	Self-Reading Dosimeter
TAC	Technical Assessment Center
TL	Team Leader
WNW	West Northwest

# APPENDIX 2

## Exercise Evaluators and Team Leaders

### EXERCISE EVALUATORS AND TEAM LEADERS

The following is a list of the personnel who will evaluate the Salem/Hope Creek Nuclear Generating Stations REP exercises on March 21, 2006 and the out of sequence activities on March 8 & 9, 2006. Evaluator Team Leader (TL) and Assistant Team Leader (ATL) are indicated by the letters after their organization's name. The organization each evaluator represents is indicated by the following abbreviations:

FAA	Federal Aviation Administration
DHS	Department of Homeland Security
NRC	Nuclear Regulatory Commission
ICF	ICF Consulting

<u>OBSERVERS-AT-LARGE</u>	<u>NAME</u>	<u>ORGANIZATION</u>
RPCC Chairman	Darrell Hammons	DHS
Project Officer	Al Henryson	DHS
ICF Regional Coordinator	Roger Kowieski	ICF

#### 1. Biennial Plume Exercise – March 21, 2006 (4:00-10:30 pm)

<u>EVALUATION SITE</u>	<u>EVALUATOR</u>	<u>ORGANIZATION</u>
<b>STATE OF DELAWARE</b>		
State Emergency Operations Center	John Price	DHS (TL)
	Chris Thompson	FAA (ATL)
	Richard Smith	ICF
	Reggie Rodgers	ICF
State Traffic And Access Control ( <i>Odessa – Troop 9</i> ) ( <i>Interview at the state EOC</i> )	Louis Sosler (located at EOC)	ICF
Emergency News Center (Woodstown, NJ)	Paul Nied	ICF
Technical Assessment Center (TAC-EOC)	Ken Wierman	DHS
Emergency Operations Facility (EOF)	Robert Bores	NRC
State Field Monitoring Team 1	Harry Harrison	ICF
State Field Monitoring Team 2	Marynette Herndon	ICF
Mass Care Facility ( <i>Brandywine High School – 5:30 pm</i> )	Gary Goldberg	ICF

<b><u>EVALUATION SITE</u></b>	<b><u>EVALUATOR</u></b>	<b><u>ORGANIZATION</u></b>
<b>RISK JURISDICTIONS</b>		
Kent County Emergency Operations Center	Angela Hough	DHS (TL)
	Jan Jackson	ICF (ATL)
	Robert Lemeshka	ICF
	Richard Wessman	ICF
New Castle County Emergency Operations Center	Wayne Shych	DHS (TL)
	Jerry Rossman	ICF (ATL)
	Robert Duggleby	ICF
	Thomas Hegele	ICF
Route Alerting ( <i>Port Penn Fire Company, Port Penn</i> )	Todd Sniffin	ICF
<b>2. Out-of-Sequence Demonstrations – March 8, 2006 (9:00 am)</b>		
<b>SCHOOLS</b>		
	Roger Kowieski	ICF (TL)
State Emergency Operations Center	Paul Nied	ICF
Appoquinimink School District (New Castle County) ( <i>Meredith Everett M.S.</i> )	Robert Lemeshka	ICF
Colonial School District (New Castle County) ( <i>Gunning Bedford M.S.</i> )	Louis Sosler	ICF
<b>MONITORING/DECON - March 8 &amp; 9, 2006</b>		
Emergency Worker Decon. Center – March 8, 2006 (1:30 pm) ( <i>DNG Middletown Readiness Center</i> )	Marynette Herndon	ICF
Reception Center – March 9, 2006 (9:00 am) ( <i>DNG Stern Readiness Center, Marshallton</i> )	Marynette Herndon	ICF

**APPENDIX 3**  
**Exercise Evaluation Area Criteria**  
**and Extent of Play Agreement**

Rev 4 (1/18/06)

**FINAL**  
**STATE OF DELAWARE**

**EXERCISE CRITERIA**  
**AND**  
**EXTENT-OF-PLAY**  
**March 2006**

---



1/18/06

---

Approved

Director, Delaware Emergency Management Agency / Date

**Real Life Emergencies Take Priority over Exercise Play**

**Revision**

**TABLE OF CONTENTS**

INTRODUCTION.....29

EVALUATION AREAS TO BE  
DEMONSTRATED.....30

## INTRODUCTION

The purpose of this document is to establish those exercise evaluation areas and corresponding Extent-of-Play parameters expected to be demonstrated during the Salem Nuclear Power Plant Plume graded exercise to be conducted on March 21, 2006.

This exercise is being conducted in close cooperation with the State of New Jersey. The New Jersey Management Office of Emergency Management (NJOEM) will submit a separate set of evaluation objectives to FEMA Region II for consideration.

These evaluation areas have been developed through reviews of past exercises, associated plans and procedures, the proposed exercise scenario, applicable FEMA guidance documents, and extensive discussions with FEMA representatives.

All demonstrations will be conducted in accordance with established plans and procedures, except as noted for specific exercise evaluation areas described herein.

Out-of-sequence evaluations for plume phase activities will be conducted during the week March 5, 2005. These locations will be designated with an (\*) with the associated objective. The activities to be demonstrated are:

- Special Facilities – Schools - March 8, 2006 at 9:00 a.m.  
Gunning Bedford Middle School - Colonial School District  
Meredith Everett Middle School - Appoquinimink School District
- Congregate Care – Interview the Red Cross Shelter Manager. - March 21, 2006 at 5:30 p.m. - Brandywine High School
- Delaware National Guard (DNG) Field Teams – DNG pre demonstrate equipment checkout, ambient radiation monitoring procedures and airborne radioiodine procedures. DNG Headquarters March 21, 2006 (3:00 p.m.)
- Emergency Worker Decontamination Center - March 8, 2006 at 1:30 p.m.
- Reception Center - Stern in Marshallton - March 9, 2006 at 10:00 a.m.

The full-scale graded plume phase exercise will be conducted on March 21, 2006 involving the risk jurisdictions and selected State agencies in Delaware. Demonstration activities will be initiated following a simulated accident at the plant.

Actions will be taken in accordance with each jurisdiction's emergency plan and procedures unless specified under the specific Extent-of-Play.

### **State Locations**

State Emergency Operations Center (EOC)  
State Technical Assessment Center (TAC)  
Emergency Operations Facility (EOF)  
Emergency News Center (ENC)  
Delaware National Guard (DNG) Field Teams

### **Plume Zone Local Jurisdictions**

New Castle County EOC  
Kent County EOC

## **EVALUATION AREA 1: EMERGENCY OPERATIONS MANAGEMENT**

### **Sub-element 1.a – Mobilization**

**Criterion 1.a.1: OROs use effective procedures to alert, notify, and mobilize emergency personnel and activate facilities in a timely manner. (NUREG-0654, A.4; D.3, 4; E.1, 2; H.4)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to alert, notify, and mobilize emergency personnel and to activate and staff emergency facilities.

#### **EXTENT-OF-PLAY**

Responsible OROs should demonstrate the capability to receive notification of an emergency situation from the licensee, verify the notification, and contact, alert, and mobilize key emergency personnel in a timely manner. Responsible OROs should demonstrate the activation of facilities for immediate use by mobilized personnel when they arrive to begin emergency operations. Activation of facilities should be completed in accordance with the plan and/or procedures. Pre-positioning of emergency personnel is appropriate, in accordance with the Extent-of-Play agreement, at those facilities located beyond a normal commuting distance from the individual's duty location or residence. Further, pre-positioning of staff for out-of-sequence demonstrations is appropriate in accordance with the Extent-of-Play agreement.

#### **State of Delaware Extent-of-Play:**

All activities must be based on the ORO's plans and procedures and completed as they would be in an actual emergency, unless noted above or otherwise indicated in the Extent-of-Play agreement.

#### **State EOC, Kent County EOC and New Castle County EOC**

Responders will pre-position at the State EOC, Kent County EOC and New Castle County EOC for exercise activities.

Mobilization will involve the primary agencies identified in the State of Delaware Radiological Emergency Plan (See List Below).

Delaware Emergency Management Agency, Kent County Emergency Management, New Castle County Office of Emergency Preparedness, Delaware National Guard, Delaware State Police, Division of Public Health, Division of Water Resources, Division of Social Services, Division of Fish and Wildlife, Delaware State Fire School, Delaware Department of Transportation, American Red Cross of Delmarva Peninsula, Division of Parks and Recreation and Amateur Radio.

#### **EOF**

Responders will pre-position at the Emergency Operations Facility (EOF).

**ENC**

Responders will pre-position at the Emergency News Center (ENC).

**Field Monitoring Teams**

Responders will pre-position at the DNG Headquarters.

**Locations Evaluated:**

State EOC, Kent County EOC, New Castle County EOC, DNG Field Teams, EOF, and ENC

**Outstanding Issues:**

None

## **EVALUATION AREA 1: EMERGENCY OPERATIONS MANAGEMENT**

### **Sub-element 1.b – Facilities**

**Criterion 1.b.1: Facilities are sufficient to support the emergency response. (NUREG-0654, H)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs have facilities to support the emergency response.

#### **EXTENT-OF-PLAY**

Facilities will only be specifically evaluated for this criterion if they are new or have substantial changes in structure or mission. Responsible OROs should demonstrate the availability of facilities that support the accomplishment of emergency operations. Some of the areas to be considered are: adequate space, furnishings, lighting, restrooms, ventilation, backup power and/or alternate facility (if required to support operations).

#### **State of Delaware Extent-of-Play:**

Facilities will be set up based on the ORO's plans and procedures and demonstrated, as they would be in an actual emergency, unless noted above or otherwise indicated in the Extent-of-Play agreement. Twenty-four hour rosters will be available for key players at each EOC.

#### **Locations Evaluated:**

State EOC, Kent County EOC, New Castle County EOC, and Mass Care Center

#### **Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center - DNG Middletown Readiness Center  
Reception Center - DNG Stern Readiness Center/Marshallton

#### **Outstanding Issues:**

None

## **EVALUATION AREA 1: EMERGENCY OPERATIONS MANAGEMENT**

### **Sub-element 1.c – Direction and Control**

**Criterion 1.c.1: Key personnel with leadership roles for the ORO provide direction and control to that part of the overall response effort for which they are responsible. (NUREG-0654, A.1.d, A.2.a, b)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs have the capability to control their overall response to an emergency.

#### **EXTENT-OF-PLAY**

Leadership personnel should demonstrate the ability to carry out essential functions of the response effort, for example: keeping the staff informed through periodic briefings and/or other means, coordinating with other appropriate OROs, and ensuring completion of requirements and requests.

#### **State of Delaware Extent-of-Play:**

All activities associated with direction and control will be performed based on the ORO's plans and procedures and completed, as they would be in an actual emergency.

#### **Locations Evaluated:**

State EOC, Kent County EOC and New Castle County EOC

#### **Outstanding Issues:**

None

## **EVALUATION AREA 1: EMERGENCY OPERATIONS MANAGEMENT**

### **Sub-element 1.d – Communications Equipment**

**Criterion 1.d.1: At least two communication systems are available, at least one operates properly, and communication links are established and maintained with appropriate locations. Communications capabilities are managed in support of emergency operations. (NUREG-0654, F.1, 2)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should establish reliable primary and backup communication systems to ensure communications with key emergency personnel at locations such as the following: appropriate contiguous governments within the emergency planning zone (EPZ), Federal emergency response organizations, the licensee and its facilities, emergency operations centers (EOC), and field teams.

#### **EXTENT-OF-PLAY**

ORO's will demonstrate that a primary and at least one backup system are fully functional at the beginning of an exercise. If a communications system or system is not functional, but exercise performance is not affected, no exercise issue will be assessed. Communications equipment and procedures for facilities and field units should be used as needed for the transmission and receipt of exercise messages. All facilities and field teams should have the capability to access at least one communication system that is independent of the commercial telephone system. Responsible OROs should demonstrate the capability to manage the communication systems and ensure that all message traffic is handled without delays that might disrupt the conduct of emergency operations. OROs should ensure that a coordinated communication link for fixed and mobile medical support facilities exist.

The specific communications capabilities of OROs should be commensurate with that specified in the response plan and/or procedures. Exercise scenarios could require the failure of a communications system and the use of an alternate system.

#### **State of Delaware Extent-of-Play:**

All activities associated with the management of communications capabilities will be demonstrated based on the ORO's plans and procedures and completed as they would be in an actual emergency.

#### **Locations Evaluated:**

State EOC, TAC, DNG Field Teams, Kent County EOC and New Castle County EOC, Traffic and Access Control – Delaware State Police and Department of Transportation, and Route Alerting – Port Penn Fire Company (Port Penn)

#### **Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center – DNG Middletown Readiness Center  
Reception Center – DNG Stern Readiness Center/Marshallton

#### **Outstanding Issues:**

None

## **EVALUATION AREA 1: EMERGENCY OPERATIONS MANAGEMENT**

### **Sub-element 1.e – Equipment and Supplies to Support Operations**

**Criterion 1.e.1: Equipment, maps, displays, dosimetry, potassium iodide (KI), and other supplies are sufficient to support emergency operations. (NUREG-0654, H; J.10.a, b, e, f, j, k, J.11; K.3.a)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs have emergency equipment and supplies adequate to support the emergency response.

#### **EXTENT-OF-PLAY**

Equipment within the facility(ies) should be sufficient and consistent with the role assigned to that facility in the ORO's plans and/or procedures in support of emergency operations. Use of maps and displays is encouraged.

All instruments, including air sampling flow meters (field teams only), should be inspected, inventoried, and operationally checked before each use. They should be calibrated in accordance with the manufacturer's recommendations (or at least annually for the unmodified CDV-700 series or if there are no manufacturer's recommendations for a specific instrument; modified CDV-700 instruments should be calibrated in accordance with the recommendation of the modification manufacturer.). A label indicating such calibration should be on each instrument or verifiable by other means. Note: Field team equipment is evaluated under 4.a.1; radiological laboratory equipment under 4.c.1; reception center and emergency worker facilities' equipment is evaluated under 6.a.1; and ambulance and medical facilities' equipment is evaluated under 6.d.1.

Sufficient quantities of appropriate direct-reading and permanent record dosimetry and dosimeter chargers should be available for issuance to all categories of emergency workers that could be deployed from that facility. Appropriate direct-reading dosimeters should allow individual(s) to read the administrative reporting limits and maximum exposure limits contained in the ORO's plans and procedures.

Dosimeters should be inspected for electrical leakage at least annually and replaced, if necessary. CDV-138s, due to their documented history of electrical leakage problems, should be inspected for electrical leakage at least quarterly and replaced if necessary. This leakage testing will be verified during the exercise, through documentation submitted in the Annual Letter of Certification, and/or through a staff assistance visit.

Responsible OROs should demonstrate the capability to maintain inventories of KI sufficient for use by emergency workers, as indicated on rosters; institutionalized individuals, as indicated in capacity lists for facilities; and, where stipulated by the plan and/or procedures, members of the general public (including transients) within the plume pathway EPZ.

Quantities of dosimetry and KI available and storage locations(s) will be confirmed by physical inspection at storage location(s) or through documentation of current inventory submitted during the exercise, provided in the Annual Letter of Certification submission, and/or verified during a Staff Assistance Visit. Available supplies of KI should be within the expiration date indicated on KI bottles or blister packs. As an alternative, the ORO may produce a letter from FEMA indicating that the KI supply remains potent, in accordance with Food and Drug Administration (FDA) guidance. FEMA issues these letters based upon the findings of the certified independent laboratory that performed the analysis at the ORO's request and expense.

At locations where traffic and access control personnel are deployed, appropriate equipment (e.g., vehicles, barriers, -- cones and signs, etc.) should be available or their availability described.

**State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency. Radiological Equipment verification is included with the Annual Letter of Certification (ALC) or information is available at the State EOC. Additionally, this information will be available for the evaluator.

Traffic equipment will be simulated and not deployed for Traffic and Access Control. Radiological Emergency Worker kit (dosimeters and anti-contamination suit) will be available at the State EOC during the interview.

**Locations Evaluated:**

State EOC, DNG Field Teams (plume), Route Alerting – Port Penn Fire Company (Port Penn), and Traffic and Access Control – Delaware State Police and Department of Transportation

**Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center – DNG Middletown Readiness Center  
Reception Center – DNG Stern Readiness Center/Marshallton

**Outstanding Issues:**

None

## **EVALUATION AREA 2: PROTECTIVE ACTION DECISION-MAKING**

### **Sub-element 2.a – Emergency Worker Exposure Control**

**Criterion 2.a.1: OROs use a decision-making process, considering relevant factors and appropriate coordination, to insure that an exposure control system, including the use of KI, is in place for emergency workers including provisions to authorize radiation exposure in excess of administrative limits or protective action guides. (NUREG-0654, K.4)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that an ORO have the capability to assess and control the radiation exposure received by emergency workers and have a decision chain in place as specified in the ORO's plans and procedures to authorize emergency worker exposure limits to be exceeded for specific missions.

Radiation exposure limits for emergency workers are the recommended accumulated dose limits or exposure rates that emergency workers may be permitted to incur during an emergency. These limits include any pre-established administrative reporting limits (that take into consideration Total Effective Dose Equivalent or organ-specific limits) identified in the ORO's plans and procedures.

#### **EXTENT-OF-PLAY**

ORO's authorized to send emergency workers into the plume exposure pathway EPZ should demonstrate a capability to meet the criterion based on their emergency plans and procedures.

Responsible ORO's should demonstrate the capability to make decisions concerning the authorization of exposure levels in excess of pre-authorized levels and to the number of emergency workers receiving radiation dose above pre-authorized levels.

As appropriate, ORO's should demonstrate the capability to make decisions on the distribution and administration of KI, as a protective measure, based on the ORO's plan and/or procedures or projected thyroid dose compared with the established protective action guides (PAGs) for KI administration.

#### **State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency. The taking of KI by emergency workers will be simulated.

#### **Locations Evaluated:**

DNG Field Teams (plume), Delaware State Police, and Department of Transportation and the Port Penn Fire Company (Port Penn)

#### **Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center – DNG Middletown Readiness Center  
Reception Center – DNG Stern Readiness Center/Marshallton

**Outstanding Issues:**  
None

## EVALUATION AREA 2: PROTECTIVE ACTION DECISION-MAKING

### Sub-element 2.b – Radiological Assessment and Protective Action Recommendations and Decisions for the Plume Phase of the Emergency

**Criterion 2.b.1: Appropriate protective action recommendations are based on available information on plant conditions, field monitoring data, and licensee and ORO dose projections, as well as knowledge of on-site and off-site environmental conditions. (NUREG-0654, I.8, 10, 11 and Supplement 3)**

#### INTENT

This sub-element is derived from NUREG-0654, which indicates that OROs have the capability to independently project integrated dose from exposure rates or other information and compare the estimated dose savings with the protective action guides. OROs have the capability to choose, among a range of protective actions, those most appropriate in a given emergency situation. OROs base these choices on protective action guides (PAGs) from the ORO's plans and procedures, or EPA 400-R-92-001 and other criteria, such as, plant conditions, licensee protective action recommendations, coordination of protective action decisions with other political jurisdictions (e.g. other affected OROs), availability of appropriate in-place shelter, weather conditions, evacuation time estimates, and situations that create higher than normal risk from evacuation.

#### EXTENT-OF-PLAY

During the initial stage of the emergency response, following notification of plant conditions that may warrant offsite protective actions, the ORO should demonstrate the capability to use appropriate means, described in the plan and/or procedures, to develop protective action recommendations (PARs) for decision-makers based on available information and recommendations from the licensee and field monitoring data, if available.

When release and meteorological data are provided by the licensee, the ORO also considers these data. The ORO should demonstrate a reliable capability to independently validate dose projections. The types of calculations to be demonstrated depend on the data available and the need for assessments to support the PARs appropriate to the scenario. In all cases, calculation of projected dose should be demonstrated. Projected doses should be related to quantities and units of the PAGs to which they will be compared. PARs should be promptly transmitted to decision-makers in a prearranged format.

Differences greater than a factor of 10 between projected doses by the licensee and the ORO should be discussed with the licensee with respect to the input data and assumptions used, the use of different models, or other possible reasons. Resolution of these differences should be incorporated into the PAR if timely and appropriate. The ORO should demonstrate the capability to use any additional data to refine projected doses and exposure rates and revise the associated PARs.

**State of Delaware Extent-of-Play:**

All activities associated with the management of communications capabilities will be demonstrated based on the ORO's plans and procedures and completed as they would be in an actual emergency.

**Locations Evaluated:**

State EOC and Technical Assessment Center (TAC)

**Outstanding Issues:**

None

## **EVALUATION AREA 2: PROTECTIVE ACTION DECISION-MAKING**

### **Sub-element 2.b – Radiological Assessment and Protective Action Recommendations and Decisions for the Plume Phase of the Emergency**

**Criterion 2.b.2: A decision-making process involving consideration of appropriate factors and necessary coordination is used to make protective action decisions (PADs) for the general public (including the recommendation for the use of KI, if ORO policy). (NUREG-0654, J.9, 10.m)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which indicates that OROs have the capability to independently project integrated dose from exposure rates or other information and compare the estimated dose savings with the protective action guides. OROs have the capability to choose, among a range of protective actions, those most appropriate in a given emergency situation and base these choices on protective action guides (PAGs) from the ORO's plans and procedures, FRC Reports Numbers 5 and 7 or EPA 400-R-92-001 and other criteria, such as, plant conditions, licensee protective action recommendations, coordination of protective action decisions with other political jurisdictions (e.g. other affected OROs), availability of appropriate in-place shelter, weather conditions, evacuation time estimates, and situations that create higher than normal risk from evacuation.

#### **EXTENT-OF-PLAY**

ORO should have the capability to make both initial and subsequent PADs. They should demonstrate the capability to make initial PADs in a timely manner appropriate to the situation, based on notification from the licensee, assessment of plant status and releases, and PARs from the utility and ORO staff.

The dose assessment personnel may provide additional PARs based on the subsequent dose projections, field monitoring data, or information on plant conditions. The decision-makers should demonstrate the capability to change protective actions as appropriate based on these projections.

If the ORO has determined that KI will be used as a protective measure for the general public under off-site plans, then the ORO should demonstrate the capability to make decisions on the distribution and administration of KI as a protective measure for the general public to supplement shelter and evacuation protective actions. This decision should be based on the ORO's plan and/or procedures or projected thyroid dose compared with the established PAG for KI administration. The KI decision-making process should involve close coordination with appropriate assessment and decision-making staff.

If more than one ORO is involved in decision-making, OROs should communicate and coordinate PADs with affected OROs. OROs should demonstrate the capability to communicate the contents of decisions to the affected jurisdictions.

**State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency.

**Locations Evaluated:**

State EOC and Technical Assessment Center (TAC)

**Outstanding Issues:**

None

## **EVALUATION AREA 2: PROTECTIVE ACTION DECISION-MAKING**

### **Sub-element 2.c – Protective Action Decisions Consideration for the Protection of Special Populations**

**Criterion 2.c.1: Protective action decisions are made, as appropriate, for special population groups. (NUREG-0654, J.9, 10.c, d, e, g)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to determine protective action recommendations, including evacuation, sheltering and use of potassium iodide (KI), if applicable, for special population groups (e.g., hospitals, nursing homes, correctional facilities, schools, licensed day care centers, mobility impaired individuals, and transportation dependent individuals). Focus is on those special population groups that are (or potentially will be) affected by a radiological release from a nuclear power plant.

#### **EXTENT-OF-PLAY**

Usually, it is appropriate to implement evacuation in areas where doses are projected to exceed the lower end of the range of PAGs, except for situations where there is a high-risk environment or where high-risk groups (e.g., the immobile or infirm) are involved: In these cases, examples of factors that should be considered are weather conditions, shelter availability, Evacuation Time Estimates, availability of transportation assets, risk of evacuation vs. risk from the avoided dose, and precautionary school evacuations. In situations where an institutionalized population cannot be evacuated, the administration of KI should be considered by the OROs.

#### **State of Delaware Extent-of-Play:**

All decision-making activities associated with protective actions, including consideration of available resources, for special population groups will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency.

#### **Locations Evaluated:**

State EOC

#### **Outstanding Issues:**

None

## EVALUATION AREA 2: PROTECTIVE ACTION DECISION-MAKING

### Sub-element 2.d – Radiological Assessment and Decision-Making for the Ingestion Exposure Pathway

**Criterion 2.d.1: Radiological consequences for the ingestion pathway are assessed and appropriate protective action decisions are made based on the ORO planning criteria. (NUREG-0654, I.8; J.11)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs have the means to assess the radiological consequences for the ingestion exposure pathway, relate them to the appropriate protective action guides (PAGs), and make timely, appropriate protective action decisions to mitigate exposure from the ingestion pathway.

During an accident at a nuclear power plant, a release of radioactive material may contaminate water supplies and agricultural products in the surround areas. Any such contamination would likely occur during the plume phase of the accident, and depending on the nature of the release could impact the ingestion pathway for weeks or years.

#### EXTENT-OF-PLAY

It is expected that the ORO will take precautionary actions to protect food and water supplies, or to minimize exposure to potentially contaminated water and food, in accordance with their respective plans and procedures. Often such precautionary actions are initiated by the OROs based on criteria related to the facility's emergency classification levels (ECL). Such action may include recommendations to place milk animals on stored feed and to use protected water supplies.

The ORO should use its procedures (for example, development of a sampling plan) to assess the radiological consequences of a release on the food and water supplies. The ORO assessment should include the evaluation of the radiological analyses of representative samples of water, food, and other ingestible substances of local interest from potentially impacted areas, the characterization of the releases from the facility, and the extent of areas potentially impacted by the release. During this assessment, OROs should consider the use of agricultural and watershed data within the 50-mile EPZ. The radiological impacts on the food and water should then be compared to the appropriate ingestion PAGs contained in the ORO's plan and/or procedures. (The plan and/or procedures may contain PAGs based on specific dose commitment criteria or based on criteria as recommended by current Food and Drug Administration guidance.) Timely and appropriate recommendations should be provided to the ORO decision-makers group for implementation decisions. As time permits, the ORO may also include a comparison of taking or not taking a given action on the resultant ingestion pathway dose commitments.

The ORO should demonstrate timely decisions to minimize radiological impacts from the ingestion pathway, based on the given assessments and other information available. Any such decisions should be communicated and to the extent practical, coordinated with neighboring and local OROs.

OROs should use Federal resources, as identified in the Federal Radiological Emergency Response Plan (FRERP), and other resources (e.g., compacts, nuclear insurers, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating.

**State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 2: PROTECTIVE ACTION DECISION-MAKING

### Sub-element 2.e – Radiological Assessment and Decision-Making Concerning Relocation, Re-entry, and Return

**Criterion 2.e.1: Timely relocation, re-entry, and return decisions are made and coordinated as appropriate, based on assessments of the radiological conditions and criteria in the ORO's plan and/or procedures. (NUREG-0654, A.1.b; I.10; M)**

#### INTENT

The sub-element is derived from NUREG-0654, which provides that OROs have the capability to make decisions on relocation, re-entry, and return of the general public. These decisions are essential for the protection of the public from the direct long-term exposure to deposited radioactive materials from a severe accident at a commercial nuclear power plant.

#### EXTENT-OF-PLAY

**Relocation:** OROs should demonstrate the capability to estimate integrated dose in contaminated areas and to compare these estimates with PAGs, apply decision criteria for relocation of those individuals in the general public who have not been evacuated but where projected doses are in excess of relocation PAGs and control access to evacuated and restricted areas. Decisions are made for relocating members of the evacuated public who lived in areas that now have residual radiation levels in excess of the PAGs. Determination of areas to be restricted should be based on factors such as the mix of radionuclides in deposited materials, calculated exposure rates vs. the PAGs and field samples of vegetation and soil analyses.

**Re-entry:** Decisions should be made regarding the location of control points and policies regarding access and exposure control for emergency workers and members of the general public who need to temporarily enter the evacuated area to perform specific tasks or missions.

Examples of control procedures are the assignment of or checking for, direct reading and non direct-reading dosimeters for emergency workers; questions regarding the individual's objectives and locations expected to be visited and associated time frames; availability of maps and plots of radiation exposure rates; advice on areas to avoid; and procedures for exit including: monitoring of individuals, vehicles, and equipment, decision criteria regarding decontamination; and proper disposition of emergency worker dosimeters and maintenance of emergency worker radiation exposure records.

Responsible OROs should demonstrate the capability to develop a strategy for authorized re-entry of individuals into the restricted zone, based on established decision criteria. OROs should demonstrate the capability to modify those policies for security purposes (e.g., police patrols), for maintenance of essential services (e.g., fire protection and utilities), and for other critical functions. They should demonstrate the capability to use decision making criteria in allowing access to the restricted zone by the public for various reasons, such as to maintain property (e.g., to care for the farm animals or secure machinery for storage), or to retrieve important

possessions. Coordinated policies for access and exposure control should be developed among all agencies with roles to perform in the restricted zone. OROs should demonstrate the capability to establish policies for provision of dosimetry to all individuals allowed to re-enter the restricted zone. The extent that OROs need to develop policies on re-entry will be determined by scenario events.

**Return:** Decisions are to be based on environmental data and political boundaries or physical/geological features, which allow identification of the boundaries of areas to which members of the general public may return. Return is permitted to the boundary of the restricted area that is based on the relocation PAG.

Other factors that the ORO should consider are, for example: conditions that permit the cancellation of the emergency classification level and the relaxation of associated restrictive measures, basing return recommendations (i.e., permitting populations that were previously evacuated to reoccupy their homes and businesses on an unrestricted basis) on measurements of radiation from ground deposition; and the capability to identify services and facilities that require restoration within a few days and to identify the procedures and resources for their restoration. Examples of these services and facilities are: medical and social services, utilities, roads, schools, and intermediate term housing for relocated persons.

**State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION

### Sub-element 3.a – Implementation of Emergency Worker Exposure Control

**Criterion 3.a.1: The OROs issue appropriate dosimetry and procedures, and manage radiological exposure to emergency workers in accordance with the plans and procedures. Emergency workers periodically and at the end of each mission read their dosimeters and record the readings on the appropriate exposure record or chart. (NUREG-0654, K.3)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to provide for the following: distribution, use, collection, and processing of direct-reading dosimeters and permanent record dosimeters; provide for direct-reading dosimeters to be read at appropriate frequencies by emergency workers; maintain a radiation dose record for each emergency worker; and provide for establishing a decision chain or authorization procedure for emergency workers to incur radiation exposures in excess of protective action guides, always applying the ALARA (As Low As is Reasonably Achievable) principle as appropriate.

#### EXTENT-OF-PLAY

ORO should demonstrate the capability to provide appropriate direct-reading and permanent record dosimetry, dosimetry chargers, and instructions on the use of dosimetry to emergency workers. For evaluation purposes, appropriate direct-reading dosimetry is defined as dosimetry that allows individual(s) to read the administrative reporting limits (that are pre-established at a level low enough to consider subsequent calculation of Total Effective Dose Equivalent) and maximum exposure limits (for those emergency workers involved in life saving activities) contained in the OROs plans and procedures.

Each emergency worker should have the basic knowledge of radiation exposure limits as specified in the ORO's plan and/or procedures. Procedures to monitor and record dosimeter readings and to manage radiological exposure control should be demonstrated.

During a plume phase exercise, emergency workers should demonstrate the procedures to be followed when administrative exposure limits and turn-back values are reached. The emergency worker should report accumulated exposures during the exercise as indicated in the plans and procedures. OROs should demonstrate the actions described in the plan and/or procedures by determining whether to replace the worker, to authorize the worker to incur additional exposures or to take other actions. If scenario events do not require emergency workers to seek authorizations for additional exposure, evaluators should interview at least two emergency workers, to determine their knowledge of whom to contact in the event authorization is needed and at what exposure levels. Emergency workers may use any available resources (e.g. written procedures and/or co-workers) in providing responses.

Although it is desirable for all emergency workers to each have a direct-reading dosimeter, there may be situations where team members will be in close proximity to each other during the entire

mission and adequate control of exposure can be affected for all members of the team by one dosimeter worn by the team leader. Emergency workers who are assigned to low exposure rate areas, e.g., at reception centers, counting laboratories, emergency operations centers, and communications centers, may have individual direct-reading dosimeters or they may be monitored by dosimeters strategically placed in the work area. It should be noted that, even in these situations, each team member must still have their own permanent record dosimeter.

Individuals without specific radiological response missions, such as farmers for animal care, essential utility service personnel, or other members of the public who must re-enter an evacuated area following or during the plume passage, should be limited to the lowest radiological exposure commensurate with completing their missions.

**State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency. Dosimetry electrical leakage checks will be submitted with the ALC or available at the State EOC. Additionally, this information will be available for the evaluator. Electronic dosimetry may be substituted for SRD's at some state or local jurisdictions.

Field Monitoring Team and Port Penn Fire Company (Port Penn) will not be required to dress out in protective clothing in the field.

If directed, the suiting in anti-contamination clothing and the ingestion of KI will be simulated.

The FMTs will demonstrate the donning of protective clothing before the mission.

If required, the Port Penn Fire Company (Port Penn) will demonstrate the donning of protective clothing before or after the mission.

**Locations Evaluated:**

DNG State Field Teams, Port Penn Fire Company (Port Penn), Delaware State Police and Department of Transportation

**Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center - DNG Middletown Readiness Center  
Reception Center - DNG Stern Readiness Center/Marshallton

**Outstanding Issues:**

None

## EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION

### Sub-element 3.b – Implementation of KI Decision

**Criterion 3.b.1: KI and appropriate instructions are available should a decision to recommend use of KI be made. Appropriate record keeping of the administration of KI for emergency workers and institutionalized individuals (not the general public) is maintained. (NUREG-0654, E.7; J.10, e, f)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to provide radioprotective drugs for emergency workers, institutionalized individuals, and, if in the plan and/or procedures, to the general public for whom immediate evacuation may not be feasible, very difficult, or significantly delayed. While it is necessary for OROs to have the capability to provide KI to emergency workers and institutionalized individuals, the provision of KI to the general public is an ORO option, reflected in ORO's plans and procedures. Provisions should include the availability of adequate quantities, storage, and means of the distribution of radioprotective drugs.

#### **EXTENT-OF-PLAY**

ORO's should demonstrate the capability to make KI available to emergency workers, institutionalized individuals, and, where provided for in the ORO plan and/or procedures, to members of the general public. OROs should demonstrate the capability to accomplish distribution of KI consistent with decisions made. Organizations should have the capability to develop and maintain lists of emergency workers and institutionalized individuals who have ingested KI, including documentation of the date(s) and time(s) they were instructed to ingest KI. The ingestion of KI recommended by the designated ORO health official is voluntary. For evaluation purposes, the actual ingestion of KI is **not** necessary. OROs should demonstrate the capability to formulate and disseminate appropriate instructions on the use of KI for those advised to take it. If a recommendation is made for the general public to take KI, appropriate information should be provided to the public by the means of notification specified in the ORO's plan and/or procedures.

Emergency workers should demonstrate the basic knowledge of procedures for the use of KI whether or not the scenario drives the use of KI. This can be accomplished by an interview with the evaluator.

#### **State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency.

If directed, ingestion of KI will be simulated.

#### **Locations Evaluated:**

DNG Field Teams (plume), Delaware State Police, Department of Transportation and the Port Penn Fire Company (Port Penn)

**Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center - DNG Middletown Readiness Center.  
Reception Center - DNG Stern Readiness Center/Marshallton

**Outstanding Issues:**

Planning

## STATE FIELD MONITORING TEAM 2 (State of Delaware)

**Issue No.:** 02-04-3.b.1-P-01

**Condition:** Field team members were not aware that potassium iodide (KI) could be continued for a time period following the initial dose, nor were they aware of all the conditions for which they should not take KI.

**Possible Cause:** The SOP and dosimetry kit instructions did not provide the following information: Field team members were not aware that KI could be continued for a time period following the initial dose, nor were they aware of all the conditions for which they should not take KI.

**Reference:** NUREG-0654, E.7; J.10.e

**Effect:** Ingesting only a single dosage of KI may not adequately protect the worker from uptake of radioactive iodine into the thyroid, resulting in an increased dose to the thyroid. Not having more complete information available on possible side effects or contraindications may result in delayed response to possible adverse reactions to the KI by sensitive individuals.

**Recommendation:** More complete guidance should be provided, both in writing and in the deployment briefing. The manufacturer's insert should be provided to emergency workers.

**State Response:** The team members are instructed and screened on the use of KI and prior to assignment to the teams. Additionally, KI pertinent data is included on the Emergency Worker Card (B1) and briefed to teams by the DNG OIC at the initial team briefing. The information contained in the FDA insert is not of immediate concern and would not serve any immediate benefit to team members. [However] the manufacturer's insert has been added to all emergency worker kits.

**FEMA Response:** Even though the Field Team members may have been "instructed and screened on the use of KI prior to assignment", as stated above in the State Response, the Federal Evaluator observed that the Field Team members were not aware that KI could be continued for a time period following the initial dose, nor aware of all conditions for which they should not take KI. Providing the manufacturer's insert to the emergency workers should help correct this Planning Issue and will be re-evaluated during the next regularly scheduled federal exercise.

## **EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION**

### **Sub-element 3.c – Implementation of Protective Actions for Special Populations**

**Criterion 3.c.1: Protective action decisions are implemented for special populations other than schools within areas subject to protective actions. (NUREG-0654, E.7; J.9, 10.c, d, e, g)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to implement protective action decisions, including evacuation and/or sheltering, for all special populations. Focus is on those special populations that are (or potentially will be) affected by a radiological release from a nuclear power plant.

#### **EXTENT-OF-PLAY**

Applicable OROs should demonstrate the capability to alert and notify (e.g., provide protective action recommendations and emergency information and instructions) special populations (hospitals, nursing homes, correctional facilities, mobility impaired individuals, transportation dependent, etc). OROs should demonstrate the capability to provide for the needs of special populations in accordance with the ORO's plans and procedures.

Contact with special populations and reception facilities may be actual or simulated, as agreed to in the Extent-of-Play. Some contacts with transportation providers should be actual, as negotiated in the Extent-of-Play. All actual and simulated contacts should be logged.

#### **State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency.

List of institutionalized special populations will be available at the State EOC.

List of individual special populations will be available at the Kent County EOC and New Castle County EOC.

There will be no actual notification of special populations.

All actual and simulated contacts should be logged.

#### **Locations Evaluated:**

State EOC, Kent County EOC and New Castle County EOC

#### **Outstanding Issues:**

None

## **EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION**

### **Sub-element 3.c – Implementation of Protective Actions for Special Populations**

**Criterion 3.c.2: OROs/School officials decide upon and implement protective actions for schools. (NUREG-0654, J.10.c, d, g)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to implement protective action decisions, including evacuation and/or sheltering, for all special populations. Focus is on those special population groups that are (or potentially will be) affected by a radiological release from a nuclear power plant.

#### **EXTENT-OF-PLAY**

Applicable OROs should demonstrate the capability to alert and notify all public school systems/districts, licensed day care centers, and participating private schools within the emergency planning zone of emergency conditions that are expected to or may necessitate protective actions for students.

In accordance with plans and/or procedures, OROs and/or officials of participating public and private schools and licensed day care centers should demonstrate the capability to make and implement prompt decisions on protective actions for students. Officials should demonstrate that the decision making process for protective actions considers (e.g., either accepts automatically or gives heavy weight to) protective action recommendations made by ORO personnel, the ECL at

which these recommendations are received, preplanned strategies for protective actions for that ECL, and the location of students at the time (e.g., whether the students are still at home, en route to the school, or at the school).

Implementation of protective actions should be completed subject to the following provisions: At least one school in each affected school system or district, as appropriate, needs to demonstrate the implementation of protective actions. The implementation of canceling the school day, dismissing early, or sheltering should be simulated by describing to evaluators the procedures that would be followed. If evacuation is the implemented protective action, all activities to coordinate and complete the evacuation of students to reception centers, congregate care centers, or host schools may actually be demonstrated or accomplished through an interview process. If accomplished through an interview process, appropriate school personnel including decision making officials (e.g., superintendent/principal, transportation director/bus dispatcher), and at least one bus driver (and the bus driver's escort, if applicable) should be available to demonstrate knowledge of their role(s) in the evacuation of school children. Communications capabilities between school officials and the buses, if required by the plan and/or procedures, should be verified.

Officials of the participating school(s) or school system(s) should demonstrate the capability to develop and provide timely information to OROs for use in messages to parents, the general public, and the media on the status of protective actions for schools.

**State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency.

Will demonstrate protective actions for schools as an out-of-sequence activity during March 8, 2006 at 9:00 a.m.

School principals or designees, Superintendent or designees, and bus drivers will be interviewed on procedures. A bus will be available at each school, for equipment (communications and maps) observation. However, the school children will not be involved with the demonstration nor will the buses be driven to the designated routes. The Department of Education (DOE) representative at the State EOC will demonstrate their procedures.

Private schools, private kindergartens and licensed day cares do not participate in REP Exercises. However, OROs will be prepared to show evaluators list of these facilities that they will contact in the event of an emergency in accordance with their plans and procedures.

The licensed day care notification process will be demonstrated at the State EOC on March 21, 2006. List of licensed day cares will be available at the State EOC. The process of notification procedures will be demonstrated and documented. There will be no actual notification of licensed day cares.

**\*Locations evaluated:****Out-of Sequence Demonstrations:**

Meredith Everett Middle School – Appoquinimink School District - March 8, 2006

Gunning Bedford Middle School – Colonial School District - March 8, 2006

State EOC/Department of Education Representative - March 8, 2006

State EOC for Licensed Day Care Notification - March 21, 2006

**Outstanding Issues:**

None

## EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION

### Sub-element 3.d – Implementation of Traffic and Access Control

**Criterion 3.d.1: Appropriate traffic and access control is established. Accurate instructions are provided to traffic and access control personnel. (NUREG-0654, J.10.g, j, k)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs have the capability to implement protective action plans, including relocation and restriction of access to evacuated/sheltered areas. This sub-element focuses on selecting, establishing, and staffing of traffic and access control points and removal of impediments to the flow of evacuation traffic.

#### EXTENT-OF-PLAY

ORO should demonstrate the capability to select, establish, and staff appropriate traffic and access control points consistent with protective action decisions (for example, evacuating, sheltering, and relocation), in a timely manner. OROs should demonstrate the capability to provide instructions to traffic and access control staff on actions to take when modifications in protective action strategies necessitate changes in evacuation patterns or in the area(s) where access is controlled.

Traffic and access control staff should demonstrate accurate knowledge of their roles and responsibilities. This capability may be demonstrated by actual deployment or by interview in accordance with the Extent-of-Play agreement.

In instances where OROs lack authority necessary to control access by certain types of traffic (rail, water, and air traffic), they should demonstrate the capability to contact the State or Federal agencies with authority to control access.

#### **State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency, unless indicated in the Extent-of-Play agreement.

Interviews will be conducted at the State EOC out-of-sequence between 6:00 p.m. and 7:00 p.m. which may not be within exercise play. There will be no actual deployment of Access Control and Traffic Control Points.

Delaware State Police and Department of Transportation personnel will be interviewed on Traffic and Access Control procedures and will demonstrate communication system, as well as exposure control procedures. DSP and DelDOT personnel will simulate reporting to the Emergency Worker Decontamination Center (National Guard Readiness Center) in Middletown, DE.

If directed, suiting in anti-contamination clothing and the ingestion of KI will be simulated.

**Locations Evaluated:**

Department of Transportation, Delaware State Police, and State EOC

**Outstanding Issues:**

None

## EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION

### Sub-element 3.d – Implementation of Traffic and Access Control

**Criterion 3.d.2: Impediments to evacuation are identified and resolved. (NUREG-0654, J.10; K)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs have the capability to implement protective action plans, including relocation and restriction of access to evacuated/sheltered areas. This sub-element focuses on selecting, establishing, and staffing of traffic and access control points and removal of impediments to the flow of evacuation traffic.

#### **EXTENT-OF-PLAY**

ORO should demonstrate the capability, as required by the scenario, to identify and take appropriate actions concerning impediments to evacuation. Actual dispatch of resources to deal with impediments, such as wreckers, need not be demonstrated; however, all contacts, actual or simulated should be logged.

#### **State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency, unless indicated in the Extent-of-Play agreement.

Interviews will be conducted at the State EOC.

There will be no actual deployment of Access Control and Traffic Control points.

Radiological Emergency Worker kits (dosimeters and anti-contamination suits) will be available at the State EOC during the interview.

If directed, suiting in anti-contamination clothing and the ingestion of KI will be simulated.

DSP and DelDOT personnel will simulate reporting to the Emergency Worker Decontamination Center (National Guard Readiness Center) in Middletown, DE.

#### **Locations Evaluated:**

Delaware State Police and Department of Transportation, State EOC

#### **Outstanding Issues:**

None

## **EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION**

### **Sub-element 3.e – Implementation of Ingestion Pathway Decisions**

**Criterion 3.e.1: The ORO demonstrates the availability and appropriate use of adequate information regarding water, food supplies, milk, and agricultural production within the ingestion exposure pathway emergency planning zone for implementation of protective actions. (NUREG-0654, J.9, 11)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to implement protective actions, based on criteria recommended by current Food and Drug Administration guidance, for the ingestion pathway emergency planning zone (IPZ), the area within an approximate 50-mile radius of the nuclear power plant. This sub-element focuses on those actions required for implementation of protective actions.

#### **EXTENT-OF-PLAY**

Applicable OROs should demonstrate the capability to secure and utilize current information on the locations of dairy farms, meat and poultry producers, fisheries, fruit growers, vegetable growers, grain producers, food processing plants, and water supply intake points to implement protective actions within the ingestion pathway EPZ.

OROs should use Federal resources as identified in the FRERP, and other resources (e.g. compacts, nuclear insurers, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating in the exercise.

#### **State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION

### Sub-element 3.e – Implementation of Ingestion Pathway Decisions

**Criterion 3.e.2: Appropriate measures, strategies, and pre-printed instructional material are developed for implementing protective action decisions for contaminated water, food products, milk, and agricultural production. (NUREG-0654, E.5, 7; J.9, 11)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to implement protective actions, based on criteria recommended by current Food and Drug Administration guidance, for the ingestion pathway emergency planning zone (IPZ), the area within an approximate 50-mile radius of the nuclear power plant. This sub-element focuses on those actions required for implementation of protective actions.

#### **EXTENT-OF-PLAY**

Development of measures and strategies for implementation of ingestion pathway zone (IPZ) protective actions should be demonstrated by formulation of protective action information for the general public and food producers and processors. This includes the capability for the rapid reproduction and distribution of appropriate reproduction-ready information and instructions to pre-determined individuals and businesses. OROs should demonstrate the capability to control, restrict or prevent distribution of contaminated food by commercial sectors. Exercise play should include demonstration of communications and coordination between organizations to implement protective actions. However, actual field play of implementation activities may be simulated. For example, communications and coordination with agencies responsible for enforcing food controls within the IPZ should be demonstrated, but actual communications with food producers and processors may be simulated.

#### **State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 3: PROTECTIVE ACTION IMPLEMENTATION

### Sub-element 3.f. – Implementation of Relocation, Re-entry, and Return Decisions

**Criterion 3.f.1: Decisions regarding controlled re-entry of emergency workers and relocation and return of the public are coordinated with appropriate organizations and implemented. (NUREG-0654, M.1, 3)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs should demonstrate the capability to implement plans, procedures, and decisions for relocation, re-entry, and return. Implementation of these decisions is essential for the protection of the public from the direct long-term exposure to deposited radioactive materials from a severe accident at a commercial nuclear power plant.

#### EXTENT-OF-PLAY

**Relocation:** OROs should demonstrate the capability to coordinate and implement decisions concerning relocation of individuals, not previously evacuated, to an area where radiological contamination will not expose the general public to doses that exceed the relocation PAGs. OROs should also demonstrate the capability to provide for short-term or long-term relocation of evacuees who lived in areas that have residual radiation levels above the PAGs.

Areas of consideration should include the capability to communicate with OROs regarding timing of actions, notification of the population of the procedures for relocation, and the notification of, and advice for, evacuated individuals who will be converted to relocation status in situations where they will not be able to return to their homes due to high levels of contamination. OROs should also demonstrate the capability to communicate instructions to the public regarding relocation decisions.

**Re-entry:** OROs should demonstrate the capability to control re-entry and exit of individuals who need to temporarily re-enter the restricted area, to protect them from unnecessary radiation exposure and for exit of vehicles and other equipment to control the spread of contamination outside the restricted area. Monitoring and decontamination facilities will be established as appropriate.

Examples of control procedure subjects are: (1) the assignment of, or checking for, direct-reading and non-direct-reading dosimeters for emergency workers; (2) questions regarding the individuals' objectives and locations expected to be visited and associated timeframes; (3) maps and plots of radiation exposure rates; (4) advice on areas to avoid; and procedures for exit, including monitoring of individuals, vehicles, and equipment, decision criteria regarding contamination, proper disposition of emergency worker dosimeters, and maintenance of emergency worker radiation exposure records.

**Return:** OROs should demonstrate the capability to implement policies concerning return of members of the public to areas that were evacuated during the plume phase. OROs should demonstrate the capability to identify and prioritize services and facilities that require restoration within a few days, and to identify the procedures and resources for their restoration. Examples of

these services and facilities are medical and social services, utilities, roads, schools, and intermediate term housing for relocated persons.

Communications among OROs for relocation, re-entry, and return may be simulated; however all simulated or actual contacts should be documented. These discussions may be accomplished in a group setting.

OROs should use Federal resources as identified in the FRERP, and other resources (e.g. compacts, nuclear insurers, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating in the exercise.

**State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 4: FIELD MEASUREMENT AND ANALYSIS

### Sub-element 4.a – Plume Phase Field Measurements and Analyses

**Criterion 4.a.1: The field teams are equipped to perform field measurements of direct radiation exposure (cloud and ground shine) and to sample airborne radioiodine and particulates. (NUREG-0654, H.10; I.8, 9, 11)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to deploy field teams with the equipment, methods, and expertise necessary to determine the location of airborne radiation and particulate deposition on the ground from an airborne plume. In addition, NUREG-0654 indicates that OROs should have the capability to use field teams within the plume emergency planning zone to measure airborne radioiodine in the presence of noble gases and to measure radioactive particulate material in the airborne plume.

In the event of an accident at a nuclear power plant, the possible release of radioactive material may pose a risk to the nearby population and environment. Although accident assessment methods are available to project the extent and magnitude of a release, these methods are subject to large uncertainties. During an accident, it is important to collect field radiological data in order to help characterize any radiological release. This does not imply that plume exposure projections should be made from the field data. Adequate equipment and procedures are essential to such field measurement efforts.

#### **EXTENT-OF-PLAY**

Field teams should be equipped with all instruments and supplies necessary to accomplish their mission. This should include instruments capable of measuring gamma exposure rates and detecting the presence of beta radiation. These instruments should be capable of measuring a range of activity and exposure, including radiological protection/exposure control of team members and detection of activity on the air sample collection media, consistent with the intended use of the instrument and the ORO's plans and procedures. An appropriate radioactive check source should be used to verify proper operational response for each low range radiation measurement instrument (less than 1 R/hr) and for high range instruments when available. If a source is not available for a high range instrument, a procedure should exist to operationally test the instrument before entering an area where only a high range instrument can make useful readings.

#### **State of Delaware Extent-of-Play:**

All activities will be based on the ORO's plans and procedures and completed as they would be in an actual emergency.

Two (2) DNG Field Monitoring Teams (FMTs) will be evaluated and will pre-demonstrate instrument checkout prior to the start of the exercise. DNG Field Teams (2) will remain at the DNG Headquarters until activated. They will not be required to perform a second instrument checkout.

If the DNG State Field Monitoring Teams are requested to perform an additional air sample and count during exercise play, the FMTs will perform the tasking, but the pre-demonstration will serve as the evaluation demonstration for this criterion.

The FMTs will demonstrate the donning of protective clothing before the mission.

**If directed, suiting in anti-contamination clothing and taking of KI will be simulated. DNG Field Monitoring Teams will simulate reporting to the Emergency Worker Decontamination Center in Middletown following completion of their assignment.**

DSP and DeIDOT personnel will simulate reporting to the Emergency Worker Decontamination Center (National Guard Readiness Center) in Middletown, DE.

**\*Locations Evaluated:**

DNG Field Teams

**Outstanding Issues:**

None

## **EVALUATION AREA 4: FIELD MEASUREMENT AND ANALYSIS**

### **Sub-element 4.a – Plume Phase Field Measurements and Analyses**

**Criterion 4.a.2: Field teams are managed to obtain sufficient information to help characterize the release and to control radiation exposure. (NUREG-0654, I.8, 11; J.10.a)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to deploy field teams with the equipment, methods, and expertise necessary to determine the location of airborne radiation and particulate deposition on the ground from an airborne plume. In addition, NUREG-0654 indicates that OROs should have the capability to use field teams within the plume emergency planning zone to measure airborne radioiodine in the presence of noble gases and to measure radioactive particulate material in the airborne plume.

In the event of an accident at a nuclear power plant, the possible release of radioactive material may pose a risk to the nearby population and environment. Although accident assessment methods are available to project the extent and magnitude of a release, these methods are subject to large uncertainties. During an accident, it is important to collect field radiological data in order to help characterize any radiological release. This does not imply that plume exposure projections should be made from the field data. Adequate equipment and procedures are essential to such field measurement efforts.

#### **EXTENT-OF-PLAY**

Responsible OROs should demonstrate the capability to brief teams on predicted plume location and direction, travel speed, and exposure control procedures before deployment.

Field measurements are needed to help characterize the release and to support the adequacy of implemented protective actions or to be a factor in modifying protective actions. Teams should be directed to take measurements in such locations, at such times to provide information sufficient to characterize the plume and impacts.

If the responsibility to obtain peak measurements in the plume has been accepted by license field monitoring teams, with concurrence from OROs, there is no requirement for these measurements to be repeated by State and local monitoring teams. If the license teams do not obtain peak measurements in the plume, it is the ORO's decision as to whether peak measurements are necessary to sufficiently characterize the plume. The sharing and coordination of plume measurement information among all field teams (licensee, federal, and ORO) is essential. Coordination concerning transfer of samples, including a chain-of-custody form, to a radiological laboratory should be demonstrated.

ORO should use Federal resources as identified in the Federal Radiological Emergency Response Plan (FRERP), and other resources (e.g., compacts, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating in the exercise.

**State of Delaware Extent-of-Play:**

All activities will be demonstrated in accordance with established plans and procedures as they would in an actual emergency.

**\*Locations Evaluated:**

DNG Field Teams

**Outstanding Issues:**

None

## EVALUATION AREA 4: FIELD MEASUREMENT AND ANALYSIS

### Sub-element 4.a – Plume Phase Field Measurements and Analyses

**Criterion 4.a.3: Ambient radiation measurements are made and recorded at appropriate locations, and radioiodine and particulate samples are collected. Teams will move to an appropriate low background location to determine whether any significant (as specified in the plan and/or procedures) amount of radioactivity has been collected on the sampling media. (NUREG-0654, I.8, 9, 11)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to deploy field teams with the equipment, methods, and expertise necessary to determine the location of airborne radiation and particulate deposition on the ground from an airborne plume. In addition, NUREG-0654 indicates that OROs should have the capability to use field teams within the plume emergency planning zone to measure airborne radioiodine in the presence of noble gases and to measure radioactive particulate material in the airborne plume.

In the event of an accident at a nuclear power plant, the possible release of radioactive material may pose a risk to the nearby population and environment. Although accident assessment methods are available to project the extent and magnitude of a release, these methods are subject to large uncertainties. During an accident, it is important to collect field radiological data in order to help characterize any radiological release. This does not imply that plume exposure projections should be made from the field data. Adequate equipment and procedures are essential to such field measurement efforts.

#### EXTENT-OF-PLAY

Field teams should demonstrate the capability to report measurements and field data pertaining to the measurement of airborne radioiodine and particulates to the field team coordinator, dose assessment, or other appropriate authority. If samples have radioactivity significantly above background, the appropriate authority should consider the need for expedited laboratory analyses of these samples. OROs should share data in a timely manner with all appropriate OROs. The methodology, including contamination control, instrumentation, preparation of samples, and a chain-of-custody form for transfer to a laboratory, will be in accordance with the ORO plan and/or procedures.

ORO's should use Federal resources as identified in the FRERP, and other resources (e.g., compacts, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating in the exercise.

#### **State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency. Two (2) DNG Field Teams will pre-demonstrate ambient radiation monitoring procedures and airborne radioiodine particulate activity monitoring procedures at the DNG Headquarters prior to deployment. Delivery of samples for additional analysis will not be demonstrated. Chain of custody procedures will be described to the evaluator.

The FMTs will demonstrate the donning of protective clothing before the mission.

**\*Locations Evaluated:**

DNG Field Teams

**Outstanding Issues:**

None

## **EVALUATION AREA 4: FIELD MEASUREMENT AND ANALYSIS**

### **Sub-element 4.b – Post Plume Phase Field Measurements and Sampling**

**Criterion 4.b.1: The field teams demonstrate the capability to make appropriate measurements and to collect appropriate samples (e.g., food crops, milk, water, vegetation, and soil) to support adequate assessments and protective action decision-making. (NUREG-0654, I.8; J.11)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to assess the actual or potential magnitude and locations of radiological hazards in the ingestion emergency planning zone (IPZ) and for relocation, re-entry and return measures.

This sub-element focuses on the collection of environmental samples for laboratory analyses that are essential for decisions on protection of the public from contaminated food and water and direct radiation from deposited materials.

#### **EXTENT-OF-PLAY**

The ORO field teams should demonstrate the capability to take measurements and samples, at such times and locations as directed, to enable an adequate assessment of the ingestion pathway and to support re-entry, relocation, and return decisions. When resources are available, the use of aerial surveys and in-situ gamma measurement is appropriate. All methodology, including contamination control, instrumentation, preparation of samples, and a chain-of-custody form for transfer to a laboratory, will be in accordance with the ORO's plan and/or procedures.

Ingestion pathway samples should be secured from agricultural products and water. Samples in support of relocation and return should be secured from soil, vegetation, and other surfaces in areas that received radioactive ground deposition.

ORO's should use Federal resources as identified in the FRERP, and other resources (e.g. compacts, nuclear insurers, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating in the exercise.

#### **State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 4: FIELD MEASUREMENT AND ANALYSIS

### Sub-element 4.c – Laboratory Operations

**Criterion 4.c.1: The laboratory is capable of performing required radiological analyses to support protective action decisions. (NUREG-0654, C.3; I.8, 9; J.11)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to perform laboratory analyses of radioactivity in air, liquid, and environmental samples to support protective action decision-making.

#### EXTENT-OF-PLAY

The laboratory staff should demonstrate the capability to follow appropriate procedures for receiving samples, including logging of information, preventing contamination of the laboratory, preventing buildup of background radiation due to stored samples, preventing cross contamination of samples, preserving samples that may spoil (e.g., milk), and keeping track of sample identity. In addition, the laboratory staff should demonstrate the capability to prepare samples for conducting measurements.

The laboratory should be appropriately equipped to provide analyses of media, as requested, on a timely basis, of sufficient quality and sensitivity to support assessments and decisions as anticipated by the ORO's plans and procedures. The laboratory instrument calibrations should be traceable to standards provided by the National Institute of Standards and Technology. Laboratory methods used to analyze typical radionuclides released in a reactor incident should be as described in the plans and procedures. New or revised methods may be used to analyze atypical radionuclide releases (e.g. transuranics or as a result of a terrorist event) or if warranted by circumstances of the event. Analysis may require resources beyond those of the ORO.

The laboratory staff is qualified in radioanalytical techniques and contamination control procedures.

OROs should use Federal resources as identified in the FRERP, and other resources (e.g. compacts, nuclear insurers, etc), if available. Evaluation of this criterion will take into consideration the level of Federal and other resources participating in the exercise.

#### **State of Delaware Extent-of-Play:**

Not evaluated for this exercise.

## EVALUATION AREA 5: EMERGENCY NOTIFICATION & PUBLIC INFORMATION

### Sub-element 5.a – Activation of the Prompt Alert and Notification System

**Criterion 5.a.1: Activities associated with primary alerting and notification of the public are completed in a timely manner following the initial decision by authorized offsite emergency officials to notify the public of an emergency situation. The initial instructional message to the public must include as a minimum the elements required by current FEMA REP guidance. (10 CFR Part 50, Appendix E and NUREG-0654, E. 1, 4, 5, 6, 7)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to provide prompt instructions to the public within the plume pathway EPZ. Specific provisions addressed in this sub-element are derived from the Nuclear Regulatory Commission (NRC) regulations (10 CFR Part 50, Appendix E.IV.D.), and FEMA-REP-10, "Guide for the Evaluation of Alert and Notification systems for Nuclear Power Plants."

#### EXTENT-OF-PLAY

Responsible OROs should demonstrate the capability to sequentially provide an alert signal followed by an initial instructional message to populated areas (permanent resident and transient) throughout the 10-mile plume pathway EPZ. Following the decision to activate the alert and notification system, in accordance with the ORO's plan and/or procedures, completion of system activation should be accomplished in a timely manner (**will not be subject to specific time requirements**) for primary alerting/notification. The initial message should include the elements required by current FEMA REP guidance.

For exercise purposes, timely is defined as "the responsible ORO personnel/ representatives demonstrate actions to disseminate the appropriate information/ instructions with a sense of urgency and without undue delay." If message dissemination is to be identified as not having been accomplished in a timely manner, the evaluator(s) will document a specific delay or cause as to why a message was not considered timely.

Procedures to broadcast the message should be fully demonstrated as they would in an actual emergency up to the point of transmission. Broadcast of the message(s) or test messages is not required. The alert signal activation may be simulated. However, the procedures should be demonstrated up to the point of actual activation.

The capability of the primary notification system to broadcast an instructional message on a 24-hour basis should be verified during an interview with appropriate personnel from the primary notification system.

**State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency. Siren activation and broadcast of the EAS message will be simulated.

Alert and notification of the Delaware River area will be simulated. The Emergency Alert System (EAS) will be evaluated for an EAS message. One siren will be simulated to fail (an inject will be provided for notification of siren failure) within the Port Penn Fire Company (Port Penn) district to initiate route alerting demonstration. The message broadcast for route alerting will be played by the Fire Company prior to deployment. A roster of special populations will be provided to the evaluator. No contact will be made during the demonstration with special populations. Upon completion of the route alerting, the fire company personnel will simulate reporting to the Emergency Worker Decontamination Center (Delaware National Guard Readiness Center) in Middletown, DE.

**Locations Evaluated:**

State EOC and New Castle County EOC (For siren failure notification to Fire Company)

**Outstanding Issues:**

None

## **EVALUATION AREA 5: EMERGENCY NOTIFICATION & PUBLIC INFORMATION**

### **Sub-element 5.a – Activation of the Prompt Alert and Notification System**

**Criterion 5.a.3: Activities associated with FEMA approved exception areas (where applicable) are completed within 45 minutes following the initial decision by authorized offsite emergency officials to notify the public of an emergency situation. Backup alert and notification of the public is completed within 45 minutes following the detection by the ORO of a failure of the primary alert and notification system. (NUREG-0654, E.6 and Appendix 3.B.2.c)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to provide prompt instructions to the public within the plume pathway EPZ. Specific provisions addressed in this sub-element are derived from the Nuclear Regulatory Commission (NRC) regulations (10 CFR Part 50, Appendix E.IV.D.) and FEMA-REP-10, "Guide for the Evaluation of Alert and Notification systems for Nuclear Power Plants."

#### **EXTENT-OF-PLAY**

ORO with FEMA-approved exception areas (identified in the approved Alert and Notification System Design Report) 5-10 miles from the nuclear power plant should demonstrate the capability to accomplish primary alerting and notification of the exception area(s) within 45 minutes following the initial decision by authorized offsite emergency officials to notify the public of an emergency situation. The 45-minute clock will begin when the OROs make the decision to activate the alert and notification system for the first time for a specific emergency situation. The initial message should, at a minimum, include: a statement that an emergency exists at the plant and where to obtain additional information.

For exception area alerting, at least one route needs to be demonstrated and evaluated. The selected routes should vary from exercise to exercise. However, the most difficult route should be demonstrated at least once every six years. All alert and notification activities along the route should be simulated (e.g., the message that would actually be used is read for the evaluator, but not actually broadcast) as agreed upon in the Extent-of-Play. Actual testing of the mobile public address system will be conducted at some agreed upon location.

Backup alert and notification of the public should be completed within 45 minutes following the detection by the ORO of a failure of the primary alert and notification system. Backup route alerting needs only be demonstrated and evaluated, in accordance with the ORO's plan and/or procedures and the Extent-of-Play agreement, if the exercise scenario calls for failure of any portion of the primary system(s), or if any portion of the primary system(s) actually fails to function. If demonstrated, only one route needs to be selected and demonstrated. All alert and notification activities along the route should be simulated (e.g., the message that would actually be used is read for the evaluator, but not actually broadcast) as agreed upon in the Extent-of-

Play. Actual testing of the Public Address system will be conducted at some agreed upon location.

**State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency. One back-up route-alerting route will be demonstrated.

One siren will be simulated to fail (an inject will be provided for notification of siren failure) within the Port Penn Fire Company (Port Penn) district to initiate route alerting demonstration. The message broadcast for route alerting will be played by the Fire Company prior to deployment. A roster of special populations will be provided to the evaluator. No contact will be made during the demonstration with special populations. Upon completion of the route alerting, the fire company personnel will simulate reporting to the Emergency Worker Decontamination Center (Delaware National Guard Readiness Center), in Middletown, DE.

If required, the Port Penn Fire Company (Port Penn) will demonstrate the donning of protective clothing before or after the mission.

**Locations Evaluated:**

Port Penn Fire Company (Port Penn)

**Outstanding Issues:**

None

## **EVALUATION AREA 5: EMERGENCY NOTIFICATION & PUBLIC INFORMATION**

### **Sub-element 5.b – Emergency Information and Instructions for the Public and the Media**

**Criterion 5.b.1: OROs provide accurate emergency information and instructions to the public and the news media in a timely manner. (NUREG-0654, E.5, 7; G.3.a, G.4,a, b, c)**

#### **INTENT**

This sub-element is derived from NUREG-0654, which provides that OROs should have the capability to disseminate to the public appropriate emergency information and instructions including any recommended protective actions. In addition, NUREG-0654 provides that OROs should ensure the capability exists for providing information to the media. This includes the availability of a physical location for use by the media during an emergency. NUREG-0654 also provides that a system be available for dealing with rumors. This system will hereafter be known as the public inquiry hotline.

#### **EXTENT-OF-PLAY**

Subsequent emergency information and instructions should be provided to the public and the media in a timely manner (**will not be subject to specific time requirements**). For exercise purposes, timely is defined as “the responsible ORO personnel/representatives demonstrate actions to disseminate the appropriate information/instructions with a sense of urgency and without undue delay.” If message dissemination is to be identified as not having been accomplished in a timely manner, the evaluator(s) will document a specific delay or cause as to why a message was not considered timely.

The OROs should ensure that emergency information and instructions are consistent with protective action decisions made by appropriate officials. The emergency information should contain all necessary and applicable instructions (e.g., evacuation instructions, evacuation routes, reception center locations, what to take when evacuating, information concerning pets, shelter-in-place instructions, information concerning protective actions for schools and special populations, public inquiry telephone number, etc.) to assist the public in carrying out protective action decisions provided to them. OROs should demonstrate the capability to use language that is clear and understandable to the public within both the plume and ingestion pathway EPZs. This includes demonstration of the capability to use familiar landmarks and boundaries to describe protective action areas.

The emergency information should be all-inclusive by including previously identified protective action areas that are still valid as well as new areas. The OROs should demonstrate the capability to ensure that emergency information that is no longer valid is rescinded and not repeated by broadcast media. In addition, the OROs should demonstrate the capability to ensure that current emergency information is repeated at pre-established intervals in accordance with the plan and/or procedures.

ORO should demonstrate the capability to develop emergency information in a non-English language when required by the plan and/or procedures.

If ingestion pathway measures are exercised, OROs should demonstrate that a system exists for rapid dissemination of ingestion pathway information to pre-determined individuals and businesses in accordance with the ORO's plan and/or procedures.

ORO's should demonstrate the capability to provide timely, accurate, concise, and coordinated information to the news media for subsequent dissemination to the public. This would include demonstration of the capability to conduct timely and pertinent media briefings and distribute media releases as the situation warrants. The ORO's should demonstrate the capability to respond appropriately to inquiries from the news media. All information presented in media briefings and media releases should be consistent with protective action decisions and other emergency information provided to the public. Copies of pertinent emergency information (e.g., EAS messages and media releases) and media information kits should be available for dissemination to the media.

ORO's should demonstrate that an effective system is in place for dealing with calls to the public inquiry hotline. Hotline staff should demonstrate the capability to provide or obtain accurate information for callers or refer them to an appropriate information source. Information from the hotline staff, including information that corrects false or inaccurate information when trends are noted, should be included, as appropriate, in emergency information provided to the public, media briefings, and/or media releases.

**State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency. Press releases and EAS messages are written and approved at the State EOC. Actual broadcast of EAS messages will be simulated. The Emergency News Center (ENC) lead, Woodstown, NJ disseminates this information at the ENC. At least one media briefing will be conducted. Public inquiry calls will be initiated. The public inquiry (rumor control) at the State EOC will be staffed with two operators and will receive at least six calls to include at least two (2) identifiable trends.

**Locations Evaluated:**

State EOC, Emergency News Center (ENC), Woodstown, NJ

**Outstanding Issues:**

None

## EVALUATION AREA 6: SUPPORT OPERATION/FACILITIES

### Sub-element 6.a – Monitoring and Decontamination of Evacuees and Emergency Workers, and Registration of Evacuees

**Criterion 6.a.1: The reception center/emergency worker facility has appropriate space, adequate resources, and trained personnel to provide monitoring, decontamination, and registration of evacuees and/or emergency workers. (NUREG-0654, J.10.h; K.5.b)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs have the capability to implement radiological monitoring and decontamination of evacuees and emergency workers, while minimizing contamination of the facility, and registration of evacuees at reception centers.

#### EXTENT-OF-PLAY

Radiological monitoring, decontamination, and registration facilities for evacuees/ emergency workers should be set up and demonstrated as they would be in an actual emergency or as indicated in the Extent-of-Play agreement. This would include adequate space for evacuees' vehicles. Expected demonstration should include 1/3 of the monitoring teams/portal monitors required to monitor 20% of the population allocated to the facility within 12 hours. Prior to using a monitoring instrument(s), the monitor(s) should demonstrate the process of checking the instrument(s) for proper operation.

Staff responsible for the radiological monitoring of evacuees should demonstrate the capability to attain and sustain a monitoring productivity rate per hour needed to monitor the 20% emergency planning zone (EPZ) population planning base within about 12 hours. This monitoring productivity rate per hour is the number of evacuees that can be monitored per hour by the total complement of monitors using an appropriate monitoring procedure. A minimum of six individuals per monitoring station should be monitored, using equipment and procedures specified in the plan and/or procedures, to allow demonstration of monitoring, decontamination, and registration capabilities. The monitoring sequences for the first six simulated evacuees per monitoring team will be timed by the evaluators in order to determine whether the twelve-hour requirement can be met. Monitoring of emergency workers does not have to meet the twelve-hour requirement. However, appropriate monitoring procedures should be demonstrated for a minimum of two emergency workers.

Decontamination of evacuees/emergency workers may be simulated and conducted by interview. The availability of provisions for separately showering should be demonstrated or explained. The staff should demonstrate provisions for limiting the spread of contamination. Provisions could include floor coverings, signs and appropriate means (e.g. partitions, roped-off areas) to separate clean from potentially contaminated areas. Provisions should also exist to separate contaminated and uncontaminated individuals, provide changes of clothing for individuals whose clothing is contaminated, and store contaminated clothing and personal belongings to prevent further contamination of evacuees or facilities. In addition, for any individual found to be contaminated,

procedures should be discussed concerning the handling of potential contamination of vehicles and personal belongings.

Monitoring personnel should explain the use of action levels for determining the need for decontamination. They should also explain the procedures for referring evacuees who cannot be adequately decontaminated for assessment and follow up in accordance with the ORO's plans and procedures. Contamination of the individual will be determined by controller inject and not simulated with any low-level radiation source.

The capability to register individuals upon completion of the monitoring and decontamination activities should be demonstrated. The registration activities demonstrated should include the establishment of a registration record for each individual, consisting of the individual's name, address, results of monitoring, and time of decontamination, if any, or as otherwise designated in the plan. Audio recorders, camcorders, or written records are all acceptable means for registration.

**State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency.

DNG Stern Readiness Center in Marshallton will be demonstrated out-of-sequence.

At least six (6) evacuees will be monitored with one simulated as contaminated.

They will process one (1) male decontamination and one (1) female decontamination.

Two (2) vehicles will be demonstrated for monitoring and decontamination. One (1) clean vehicle and one (1) contaminated.

Decontamination techniques will be simulated.

Reception Center floors will not be covered with paper/plastic during this demonstration. However, the materials will be available for inspection.

**Locations Evaluated:**

**Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center – DNG Middletown Readiness Center

Reception Center – DNG Stern Readiness Center/Marshallton

## EVALUATION AREA 6: SUPPORT OPERATION/FACILITIES

### Sub-element 6.b – Monitoring and Decontamination of Emergency Worker Equipment

**Criterion 6.b.1: The facility/ORO has adequate procedures and resources for the accomplishment of monitoring and decontamination of emergency worker equipment including vehicles. (NUREG-0654, K.5.b)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs have the capability to implement radiological monitoring and decontamination of emergency worker equipment, including vehicles.

#### EXTENT-OF-PLAY

The monitoring staff should demonstrate the capability to monitor equipment, including vehicles, for contamination in accordance with the ORO's plans and procedures. Specific attention should be given to equipment, including vehicles, that was in contact with individuals found to be contaminated. The monitoring staff should demonstrate the capability to make decisions on the need for decontamination of equipment including vehicles based on guidance levels and procedures stated in the plan and/or procedures.

The area to be used for monitoring and decontamination should be set up as it would be in an actual emergency, with all route markings instrumentation, record keeping and contamination control measures in place. Monitoring procedures should be demonstrated for a minimum of one vehicle. It is generally not necessary to monitor the entire surface of vehicles. However, the capability to monitor areas such as air intake systems, radiator grills, bumpers, wheel wells, tires, and door handles should be demonstrated. Interior surfaces of vehicles that were in contact with individuals found to be contaminated should also be checked.

Decontamination capabilities, and provisions for vehicles and equipment that cannot be decontaminated, may be simulated and conducted by interview.

#### **State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency.

At least two (2) emergency workers will be monitored.

They will process one (1) male decontamination and one (1) female decontamination.

Two vehicles will be demonstrated for monitoring and decontamination, one (1) clean vehicle and one (1) contaminated.

Decontamination techniques will be simulated.

Emergency Worker Decontamination Center floors will not be covered with paper/plastic during this demonstration. However, it will be available for inspection.

**Locations Evaluated:**

**Out-of Sequence Demonstrations:**

Emergency Worker Decontamination Center – DNG Middletown Readiness Center

## EVALUATION AREA 6: SUPPORT OPERATION/FACILITIES

### Sub-element 6.c – Temporary Care of Evacuees

**Criterion 6.c.1: Managers of congregate care facilities demonstrate that the centers have resources to provide services and accommodations consistent with American Red Cross planning guidelines (found in MASS CARE-Preparedness Operations, ARC 3031). Managers demonstrate the procedures to assure that evacuees have been monitored for contamination and have been decontaminated as appropriate prior to entering congregate care facilities. (NUREG-0654, J.10.h, J.12)**

#### INTENT

This sub-element is derived from NUREG-0654, which provides that OROs demonstrate the capability to establish relocation centers in host areas. Congregate care is normally provided in support of OROs by the American Red Cross under existing letters of agreement.

#### EXTENT-OF-PLAY

Under this criterion, demonstration of congregate care centers may be conducted out of sequence with the exercise scenario. The evaluator should conduct a walk-through of the center to determine, through observation and inquiries, that the services and accommodations are consistent with ARC 3031 **In this simulation, it is not necessary to set up operations, as they would be in an actual emergency.** Alternatively, capabilities may be demonstrated by setting up stations for various services and providing those services to simulated evacuees. Given the substantial differences between demonstration and simulation of this criteria, exercise demonstration expectations should be clearly specified in extent-of-play agreements.

Congregate care staff should also demonstrate the capability to ensure that evacuees have been monitored for contamination, have been decontaminated as appropriate, and have been registered before entering the facility. This capability may be determined through an interview process.

If operations at the center are demonstrated, material that would be difficult or expensive to transport (e.g., cots, blankets, sundries, and large-scale food supplies) need not be physically available at the facility(ies). However, availability of such items should be verified by providing the evaluator a list of sources with locations and estimates of quantities.

#### **State of Delaware Extent-of-Play:**

These activities will be based on the ORO's plans and procedures and completed, as they would be in an actual emergency.

This element will be evaluated as an out-of-sequence activity. Actual set up of the center will not be demonstrated. Processes will be described to the evaluator during an interview at the designated location.

Capabilities will be demonstrated through an interview process.

Availability of additional personnel will be determined by interview.

Supplies required for long term mass care (cots, blankets, food, etc) are not to be acquired or brought to the Congregate Care Shelters.

**\*Locations Evaluated:**

Brandywine High School

**Outstanding Issues:**

None

## APPENDIX 4

# Exercise Scenario

Exercise begins at 1500. Salem Units 1 & 2 and Hope Creek are at 100% power. There is a weak low pressure cell in the Delaware Valley and winds are out of the South East at 5-10 mph. Later in the evening, a high pressure cell is expected to move into the Delaware Valley with winds shifting to out of the West South West.

- A Salem Unit 2 Reactor Coolant Pump trips. Reactor should automatically shut down. Automatic shut down does not occur. Operators successfully shut down the reactor.

1545 ALERT Declaration

- Loss of Coolant Accident (LOCA) with cladding damage. Outboard Containment Isolation Valve fails open (Inboard Valve is closed). Containment radiation readings at 465 R/hr.

1745 SAE Declaration

- Inboard Containment Isolation Valve fails open- Release path to the environment through a monitored pathway. Effluent monitor indicates 150 Curies per second release rate.

1845 GENERAL EMERGENCY Declaration. Expect a PAR to; evacuate 0-5 miles 360 degrees and 5-10 miles in the WNW-NW-NNW sectors and shelter the remaining sectors.

- 2015 Wind shift into NJ.

2030 Expect revised PAR; Add 5-10 miles evacuation in NE-ENE-E sectors.

2200 Outboard Containment Isolation Valve closed. Stops release from Containment; however, activity in the Auxiliary Building is still being released with a decreasing rate.

2230 Or later, Exercise terminate.

---

Times are when event occurs that should trigger action. Times shown for ECL declarations are controller inject times.

There is radioiodine in the release; however, the 5 rem adult thyroid trigger is exceeded only at 1 mile (assuming a 4 hour release). Since the nearest permanent population in Delaware in the plume direction is approximately 3.5 miles, Delaware is not expected to authorize KI use.

## APPENDIX 5

# Planning Issues

This appendix contains the prior Planning Issues resolved and new Planning Issues assessed during the March 21, 2006 exercise at S/HCNGS. Planning Issues are issues identified in an exercise or drill that do not involve participant performance, but rather involve inadequacies in the plan or procedures. Planning Issues are required to be corrected through the revision and update of the appropriate State and local RERPs and/or procedures in accordance with the following schedule:

- Within 120 days of the date of the exercise/drill when the Planning Issue is directly related to protection of the public health and safety.
- During the annual plan review and update (reported in the Annual Letter of Certification) when the Planning Issue does not directly affect the public health and safety. However, when the date for the annual plan review and update is imminent and the responsible organization does not have sufficient time to make the necessary revisions in the plans and/or procedures, the revised portion of the plans and/or procedures should be submitted in the subsequent annual plan review and update and reported in the Annual Letter of Certification.

Any requirement for additional training of responders to radiological emergencies necessitated by the revision and update of the plans and/or procedures must be completed within the timeframes described above in order for the Planning Issue to be considered resolved.

### State Field Monitoring Team – Prior Planning Issue Resolved

#### Issue No.: 02-04-3.b.1-P-01

**Condition:** Field team members were not aware that potassium iodide (KI) could be continued for a time period following the initial dose, nor were they aware of all the conditions for which they should not take KI.

**Corrective Action Demonstrated:** During the March 21, 2006 exercise, Field Team Members were cognizant of the time periods and conditions during which KI could be administered. They were also aware of conditions for which KI should not be ingested.

The IOSAT™ flyer with KI information is now included in the Emergency Worker Response Kit.

## State Field Monitoring Team – New Planning Issue

### Issue No.: 02-06-2.a.1-P-01

**Condition:** Interchangeable use of R and Rem in some procedures, i.e. Standard Operating Procedure (SOP) 801.

**Possible Cause:** Inattention to detail during plan revisions.

**Reference:** State of Delaware SOP 801

**Effect:** Dosimetry used in the field reads in units of R whereas the turnback levels and Dose limits in the procedure are in Rem. Rem implies an internal dose component as well as an external dose.

**Recommendation:** Review the procedures for the use of R and Rem and consider the appropriateness of the levels. Field dosimetry measures are in units of R and are reported as such.

**State Response:** DEMA will review and revise procedures as necessary for clarification of the use of R and Rem in SOP 801.

**Schedule for Corrective Action:** This issue will be addressed during the next scheduled REP Plan update and re-evaluated during the next scheduled graded REP exercise.

**FEMA Response:** Concur. This will be evaluated during the next graded REP exercise.